

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251486
Address: 1043 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, June 26, 2025

Corrective Action Required:

1	Misc	1043 sw fiord FB = Fire block
		<ul style="list-style-type: none">- Fb top of chase garage fur out to soffit at pantry- Fb end of soffit near pantry- Truss screws in dining area not installed through second top plate (correct)-- Header off joist landing on non load bearing wall owner entry/ kitchen HVAC chase into foyer-- Provide hold down for double girder truss in bedroom 2-

Comments: