

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250281
Address: 2754 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Thursday, June 26, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Driveway and sidewalk inspection pending- Final grading and sod- Add gravel to water meter pit- Missing downspout on back corner at deck- Sump discharge to be 36" away from foundation- Provide splash pads for downspouts
---	------	--

Comments: