

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20246285  
Address: 1333 SW WINTHROP TER, LEES SUMMIT, MO 640811331 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Friday, June 27, 2025

Corrective Action Required:

1	Misc	Both sides
		-address rafter to ceiling joist connections (N and S walls)
		-
		1331
		-fire block around beam N wall in basement
		-tighten anchor bolts where loose throughout basement
		-fireblock bed 4 S wall into furr down
		1333
		-seal penetrations in roof decking (see vent)

**Comments:**