

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245090
Address: 2775 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, June 30, 2025

Corrective Action Required:

1	Misc	- Provide (2) 1/2" through bolts on each post to beam connections at deck - Provide secondary lock at sliding door - Receptacle at sump to be labeled non GFCI
---	------	--

Comments: