CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251162

Address: 638 SE BRADFREE ST, LEES SUMMIT, MO 64063640 SE BRADFREE ST, LEES SUMMIT, MO 64063642

SE BRADFREE ST, LEES SUMMIT, MO 64063636 SE BRADFREE ST, LEES SUMMIT, MO

64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Control Inspection Mitchell Schwarz Failed Tuesday, July 01, 2025

Corrective Action Required:

1 Misc No further inspections until erosion control in compliance

-clean storm drain top and inlet

-clean curb and street-repair downed silt fence

Comments: