

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20236155  
Address: 2354 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                       | Inspector:   | Outcome: | Date:                  |
|---------------------------------------------------|--------------|----------|------------------------|
| <b>Erosion Control Inspection<br/>Residential</b> | Drew Fischer | Failed   | Tuesday, July 01, 2025 |

Corrective Action Required:

|   |      |                                                    |
|---|------|----------------------------------------------------|
| 1 | Misc | - Remove stock pile<br>- Protect perimeter of lot. |
|---|------|----------------------------------------------------|

Corrective Action Required:

|   |                            |                                                                                               |
|---|----------------------------|-----------------------------------------------------------------------------------------------|
| 2 | DCM3 ESC<br>REQUIRED 2 DAY | EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE<br>WITHIN TWO BUSINESS DAYS. |
|---|----------------------------|-----------------------------------------------------------------------------------------------|

**Comments:**