



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20112915
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Inspected On: Wednesday, February 22, 2012
Inspected By: John Borns Joe Dir Joe Dir
Expiration Date: 4/12/2012 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, February 22, 2012

Corrective Action Required:
2 MISC RESOLVE PLANNING & DEVELOPMENT ISSUES;
RE-INSPECTION TO BE REQUESTED WHEN FINISH
SITWORK IS COMPLETED.

Corrective Action Required:
3 MISC RESOLVE PUBLIC WORKS ISSUES

Sprinkler - Flow Test	Joe Dir	Passed	Wednesday, February 22, 2012
Occupancy Inspection - Fire	Joe Dir	Passed	Wednesday, February 22, 2012

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | MISC | (1) label all mechanical and electrical rooms from the corridor
(2) label the isolation valve for the sprinkler system in the water manifold closet
(3) remove all dust covers from the smoke detectors throughout
(4) confirm the mag lock on the man door exit drops off on alarm activation |
|---|------|---|

Corrective Action Required:

- | | | |
|---|------|---|
| 2 | MISC | All pending issues from previous inspection have been corrected |
|---|------|---|

Comments: