CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251486

Address: 1043 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: All Rough Inspection -Shawn Hoffman Failed Wednesday, July 02, Residential 2025 Corrective Action Required: Misc 1043 sw fiord 1 FB = Fire block - Fb top of chase garage fur out to soffit at pantry - Fb end of soffit near pantry - Truss screws in dining area not installed through second top plate (correct) - Header off joist landing on non load bearing wall owner entry/kitchen HVAC chase into foyer - Provide hold down for double girder truss in bedroom 2 Corrective Action Required: 2 Misc No change Not ready

Comments: