






THE P.E. CERTIFICATION PROVIDED HEREIN PERTAINS
TO THE SIGNATURE OF THE INDIVIDUAL NAMED
STRUCTURAL COMPONENTS ONLY. ALL
OTHER AREAS ARE WITHIN THE SCOPE OF
WORK OF THIS CERTIFICATION.



Uprights 18'x42" Teardrop
NEW ERA PRODUCTS
96x4" beams MECALUX
BEAMS CAP/shelf
42x46 Wire decking
(2500 lbs cap w/material
handling)



Single Sided Cantilever
(MECALUX)
12'tall with COL.H23 C W
8"x18 U 12
BASE H23 W 8"x18 U 4'
48" Straight Arm H23
S5"x10 U 4'



Uprights 8'x36" Teardrop
Reel Rack 3' wide



Uprights 8'x36" Teardrop
Reel Rack 4' wide




JOB NAME: BUTLER SUPPLY
LOCATION: 2736 NE MCBAIN
DR
Lees Summit MO 64064





NOTES:
USE @ ALL
COLUMN/BASE LOCATIONS TYP.

DESCRIPTION	BASE PLATE: 5.094" X 4.688"	DESCRIPTION	COLUMN: MCLX 314	DESCRIPTION	BRACING: HORIZ. & DIAG.	NOTES: USE @ ALL MCLX BRACE LOCATIONS TYP.
MATERIAL	0.194" THICK PLATE	MATERIAL	14 GAGE THK STEEL	MATERIAL	16 GAGE STEEL (C456)	
STEEL YIELD	ASTM A36, Fy=36,000 PSI	STEEL YIELD	ASTM A570, Fy=55,000 PSI	STEEL YIELD	ASTM A570, Fy=55,000 PSI	




DESCRIPTION	3-TAB CONNECTOR	NOTES: USE @ ALL BEAM TO COLUMN CONNECTION LOCATIONS TYP.	DESCRIPTION	4" BEAM (INTLK 40E)	NOTES: USE @ ALL BEAM LOCATIONS TYP.
MATERIAL	7 GAGE		MATERIAL	16 GAGE	
STEEL YIELD	ASTM A570, Fy=55,000 PSI		STEEL YIELD	ASTM A570, Fy=55,000 PSI	

SEE ATTACHED PALLET RACK KC DWG.
FOR STORAGE RACK ELEVATIONS.




GENERAL PROJECT NOTES

- DESIGNED PER REQUIREMENTS OF THE 2018 IBC, ASCE 7-16 AND THE 2012 RMI RACK DESIGN MANUAL
3. SEISMIC CRITERIA $S_s = 0.099$, $S_1 = 0.068$, $F_a = 1.600$, $F_w = 2.400$
- $I_p = 1.0$ (NO PUBLIC ACCESS), $S_{ds} = 0.106$, $S_{d1} = 0.109$, OCC. CATAG. II,
- SITE CLASS D-DEFAULT, SEISMIC DESIGN CATEG. B
3. STORAGE CAPACITY:
- TYPE 1 SELECTIVE RACK = 3000 LBS PER LEVEL TYP.
4. ANCHORS: 4 HILTI KWIKBOLT T22 ESR #4266 (50 FT-LBS TORQUE), OR POWERS SDC2 ESR#2502 (40 FT-LBS TORQUE)
1/2" O x 3-1/4" MIN. EMBED.
- (1) ANCHOR PER BASE PLATE
5. PERIODIC SPECIAL INSPECTION IS REQUIRED DURING ANCHOR INSTALLATION. ANCHORS SHALL BE INSTALLED PER ICC ESR#4266.
6. EXISTING S.O.G. CONCRETE THICKNESS & COMPRESSIVE STRENGTH, 6" x 4000 PSI
7. SOIL BEARING PRESSURE 750 PSF.
8. ALL RACK INSTALLATIONS AND RACKS MANUFACTURED IN CONFORMITY WITH THIS STANDARD SHALL DISPLAY IN ONE OR MORE CONSPICUOUS LOCATIONS A PERMANENT PLaque EACH NOT LESS THAN 50 SQUARE INCHES IN AREA AND SHOWING THE MAXIMUM PERMISSIBLE UNIT LOAD IN CLEAR, LEGIBLE PRINT.
9. ALL BOLTS GR. 5 OR BETTER, INSTALL TO SNUG TIGHT FIT OR BETTER
10. ALL WELDING PERFORMED IN THE SHOP OF AN APPROVED FABRICATOR BY AWS CERTIFIED WELDERS USING E70XX ELECTRODE OR BETTER. NO FIELD WELDING PERFORMED. SPECIAL INSPECTION IS REQUIRED ONLY FOR ANY FIELD WELDING.
11. THE CLEAR SPACE BELOW SPRINKLERS SHALL BE A MIN. OF 18" BETWEEN TOP OF THE STORAGE AND THE CEILING SPRINKLER DEFLECTOR.
12. THE PRODUCT SHOWN ON THE DETAILS HEREIN IS ASSUMED TO BE IN GOOD, UNDAMAGED CONDITION. THE PRODUCT MUST BE FREE OF ANY DAMAGE AND/OR FABRICATION DEFICIENCIES OR IRREGULARITIES. IT IS THE RESPONSIBILITY OF THE OWNER, USER, PRODUCT PROVIDER AND/OR INSTALLER OF THE COMPONENTS TO NOTIFY SED, INC IN WRITING, OF ANY DAMAGE, DEFICIENCIES OR IRREGULARITIES.
13. IT IS THE RESPONSIBILITY OF THE OWNER AND/OR USER OF THE COMPONENTS SHOWN HEREIN TO NOTIFY SED, INC OF ANY DAMAGE OR DEFICIENCIES IN THE SYSTEM DURING USE. THIS INCLUDES SUCH OCCURRENCES SUCH AS IMPACT DAMAGE TO THE COMPONENTS FROM FORKLIFT OR HEAVY MACHINERY, IMPACT FROM DROPPED LOADS ON THE SYSTEM, DAMAGE TO SYSTEMS BY IMPROPER USE OR INSTALLATION, ETC. THE USER OF THE PRODUCT MUST NOTIFY SED, INC IN WRITING SHOWING ANY DAMAGE OR DEFICIENCY OCCUR TO THE PRODUCT SHOWN HEREIN. IT IS THE RESPONSIBILITY OF THE OWNER AND/OR USER TO MAINTAIN THE SAFETY AND PROPER USE OF THE STORAGE PRODUCT SHOWN HEREIN.
14. IT IS THE RESPONSIBILITY OF THE OWNER/USER OF THE STORAGE SYSTEM SHOWN HEREIN TO REPAIR OR REPLACE ANY COMPONENT THAT IS DAMAGED OR OTHERWISE DEFICIENT.
15. THE OWNER SHALL MAINTAIN THE STRUCTURAL INTEGRITY OF THE RACK SYSTEM BY ASSURING PROPER OPERATIONAL, HOUSE KEEPING AND MAINTENANCE PROCEDURES, BUT NOT LIMITED TO THE FOLLOWING:
- a. PROHIBIT ANY OVER LOADING OF ANY PALLET POSITIONS AND OF OVERALL RACK SYSTEMS.
- b. REGULARLY INSPECT FOR DAMAGE. IF DAMAGE IS FOUND, IMMEDIATELY UNLOAD THE AFFECTED AREA AND REPLACE OR REPAIR ANY DAMAGED COLUMNS, BEAMS, OR OTHER STRUCTURAL COMPONENTS.
- c. REQUIRE ALL PALLETS TO BE MAINTAINED IN GOOD, SAFE, OPERATING CONDITION.
- d. ENSURE THAT PALLETS ARE PROPERLY PLACED ONTO PALLET LOAD SUPPORT MEMBERS IN PROPERLY STACKED AND STABLE POSITION.
- e. REQUIRE THAT ALL GOODS STORED ON EACH PALLET TO BE PROPERLY STACKED AND STABLE.
- f. PROHIBIT DOUBLE STACKING OF ANY PALLET POSITION, INCLUDING THE TOP MOST POSITION, UNLESS THE RACK SYSTEM IS SPECIFICALLY DESIGNED FOR SUCH LOADING.
- g. THE OWNER AND/OR USER OF THE RACK SYSTEM MUST PROVIDE MEASURES TO MITIGATE DAMAGE TO THE STORAGE RACK BY USE OF IMPACT PROTECTIVE DEVICES IN AREAS WHERE FORKLIFT AND/OR HEAVY MACHINERY ARE IN USE.



NOTES:
CONFIRM O.A.L. OF ANCHORS WITH INSTALLER TO
ENSURE REQUIRED EMBEDMENT IS OBTAINED.

DESCRIPTION	HILTI KWIKBOLT TZ2 ANCHOR	NOTES: SEE NOTE #4 ABOVE FOR ANCHOR SPECS.
SIZE	1/2"Ø X 3-1/4" MIN. EMBED.	
ESR#	4266	



NOTES:
USES (3) ROW SPACERS FOR DOUBLE ROW UNITS

DESCRIPTION	STD ROW SPACER	NOTES: ATTACH WITH (4) 5/16"Ø GR. 5 BOLTS, (2) @ EACH END
MATERIAL	14 GAGE	
STEEL YIELD	ASTM A570, Fy=55,000 PSI	



DESCRIPTION	STORAGE RACK ELEVATIONS
-------------	-------------------------

	DATE	REV.	REVISION

STRUCTURAL
ENGINEERING & DESIGN INC.,
1015 WRIGHT AVE. | A. VERNICA 91750 PHONE 909.596.1351 FAX 909.596.7186

1815 WRIGHT AVE | A VERNE, CA 91750 PHONE 909 596 1351 FAX 909 596 7186

BUTLER SUPPLY
2736 NE MCBAIN DR
LEE'S SUMMIT, MO 64064

LEE'S SUMMIT, MO 64064

CLIENT PALLET RACK KC

DATE 06/06/00

DRAWN BY DAS ENG. BY BOB

MECALUX


TYPE STORAGE BACK

JOB N°



25-0625-3

SHEET NO.

SED 1 OF 2




COLUMN W8"X 18#



DESCRIPTION	BASE: STRUCTURAL	DESCRIPTION	COLUMN: STRUCTURAL
MATERIAL	W8" X 18#	MATERIAL	W8" X 18#
STEEL YIELD	ASTM A572, Fy=36,000 PSI	STEEL YIELD	ASTM A572, Fy=36,000 PSI


NOTES:
USE @ ALL SGL SIDED STRUCTURAL BASE TO COLUMN LOCATIONS.
ATTACH W/ 3/4"Ø ASTM A325 BOLTS COLUMN TO BASE.



NOTES:
USE @ ALL ARM LOCATIONS TYP.
ALL LOADS TO BE EVENLY DISTRIBUTED OVER ALL ARMS. NO TIP LOADING ALLOWED.

DESCRIPTION	4" STRUCTURAL ARM	NOTES: ATTACH W/ (4) 3/4" DIA. ASTM A325 BOLTS.
MATERIAL	S5" X 10#	
STEEL YIELD	ASTM A572, Fy=50,000 PSI	

SEE NOTE # 4 ANCHOR DETAILS AND PLACEMENT	
DESCRIPTION	ANCHOR PLAN




Technical drawing of a base plate and anchor bolt assembly. The drawing shows a cross-section of a base plate with a threaded anchor bolt passing through it. The bolt has a hexagonal head and a threaded shank. The base plate is labeled "BASE PLATE". The drawing includes dimension lines and labels: "O.A.L." (Overall Length) for the total height, "F.F." (Finish Face) for the top surface, "4-3/4" MIN. EMBED." for the minimum embedment length, and "3/4" for the diameter of the bolt shank.

NOTES:
CONFIRM O.A.L. OF ANCHORS WITH INSTALLER TO
ENSURE REQUIRED EMBEDMENT IS OBTAINED.

DESCRIPTION	HILTI KWIKBOLT TZ2 ANCHOR	
SIZE	3/4"Ø x 4-3/4" MIN. EMBED.	NOTE:
ESR#	4266	SEE NOTE #4 ABOVE FOR ANCHOR SPECS.


NOTES:
USE @ ALL BRACE LOCATIONS TYP.

DESCRIPTION	HORIZ. C-BRACE	DESCRIPTION	DIAG. BRACE
MATERIAL	L2" X L2" X 3/16"	MATERIAL	1.5625" X 1/8" STRAP
STEEL YIELD	ASTM A36, Fy=36,000 PSI	STEEL YIELD	ASTM A36, Fy=36,000 PSI




SEE ATTACHED PALLET RACK KC DWG.
FOR CANTI. RACK ELEVATIONS

NOTE: CANTILEVER RACK ELEVATIONS



DESCRIPTION	BRACE CLIP	NOTES: USE @ ALL BRACE TO COLUMN CONNECTION LOCATIONS TYP.
MATERIAL	3/16" THK	
STEEL YIELD	ASTM A36, Fy=36,000 PSI	



DESCRIPTION	BRACE TO COLUMN CONNECTION
-------------	----------------------------

NOTE: CANTILEVER RACK ELEVATIONS

GENERAL PROJECT NOTES

- DESIGNED PER REQUIREMENTS OF THE 2018 IBC, ASCE 7-16, SECTION 15.5.3, & 2012 RMI RACK DESIGN MANUAL.
- DESIGNED CRITERIA Ss = 0.099, S1 = 0.068, Fa = 1.600, Fv = 2.400.
- Ip = 1.0 (NO PUBLIC ACCESS), Sds = 0.166, S1 = 0.109, OCCUPANCY CATAG. II
- TYPE CLASS D-DEFAULT, Seismic Design Catag. B
3. STORAGE CAPACITY:
- TYPE 2 SGL-SIDED CANTILEVER = 1000# UNIFORM LOAD PER ARM LEVEL TYP.
4. ANCHORS: HILTI KWIKBOLT T22 ESR#4266 (110 FT-LBS TORQUE), OR POWERS SD2 ESR#2502 (110 FT-LBS TORQUE)
- 3/4"O X 4-3/4" MIN. EMBED.
- (4) ANCHORS PER BASE PLATE, (2) @ TOE, (2) @ COLUMN.
5. PERIODIC SPECIAL INSPECTION IS REQUIRED DURING ANCHOR INSTALLATION. ANCHORS SHALL BE INSTALLED PER ICC ESR#4266.
6. EXISTING S.O.G. CONCRETE THICKNESS & COMPRESSIVE STRENGTH, 6" x 4000 PSI
7. SOIL BEARING PRESSURE 750 PSF.
8. ALL RACK INSTALLATIONS AND RACKS MANUFACTURED IN CONFORMITY WITH THIS STANDARD SHALL DISPLAY IN ONE OR MORE CONSPICUOUS LOCATIONS A PERMANENT PLaque EACH NOT LESS THAN 150 SQUARE INCHES IN AREA AND SHOWING THE MAXIMUM PERMISSIBLE UNIT LOAD IN CLEAR, LEGIBLE PRINT.
9. ALL BOLTS ASTM A336 OR BETTER, INSTALL TO SNUG TIGHT FIT OR BETTER
10. ALL WELDING PERFORMED IN THE SHOP OF AN APPROVED FABRICATOR BY AWS CERTIFIED WELDERS USING E70XX ELECTRODE OR BETTER. FIELD WELDS, IF ANY, SHALL BE PROVIDED UNDER THE SUPERVISION OF A LICENSED WELDING INSPECTOR. SPECIAL INSPECTION IS REQUIRED FOR ALL STRUCTURAL WELDS EXCEPT FOR WELDING DONE IN AN APPROVED FABRICATOR'S SHOP.
11. THE CLEAR SPACE BELOW SPRINKLERS SHALL BE A MIN. OF 18" BETWEEN TOP OF THE STORAGE AND THE CEILING SPRINKLER DEFLECTOR.
12. THE PRODUCT SHOWN ON THE DETAILS HEREIN IS ASSUMED TO BE IN GOOD, UNDAMAGED CONDITION. THE PRODUCT MUST BE FREE OF ANY DAMAGE AND/OR FABRICATION DEFICIENCIES OR IRREGULARITIES. IT IS THE RESPONSIBILITY OF THE OWNER, USER, PRODUCT PROVIDER AND/OR INSTALLER OF THE COMPONENTS TO NOTIFY SED, INC IN WRITING, OF ANY DAMAGE, DEFICIENCIES OR IRREGULARITIES.
13. IF IT IS THE RESPONSIBILITY OF THE OWNER AND/OR USER OF THE COMPONENTS SHOWN HEREIN TO NOTIFY SED, INC OF ANY DAMAGE OR DEFICIENCIES IN THE SYSTEM DURING USE THIS INCLUDES SUCH OCCURRENCES SUCH AS IMPACT DAMAGE TO THE COMPONENTS FROM FORKLUFT OR HEAVY MACHINERY, IMPACT FROM DROPPED LOADS ON THE SYSTEM, DAMAGE TO SYSTEMS BY IMPROPER USE OR INSTALLATION, ETC. THE USER OF THE PRODUCT MUST NOTIFY SED, INC IN WRITING SHOULD ANY DAMAGE OR DEFICIENCY OCCUR TO THE PRODUCT SHOWN HEREIN. IT IS THE RESPONSIBILITY OF THE OWNER AND/OR USER TO MAINTAIN THE SAFETY AND PROPER USE OF THE STORAGE PRODUCT SHOWN HEREIN.
14. IF IT IS THE RESPONSIBILITY OF THE OWNER/USER OF THE STORAGE SYSTEM SHOWN HEREIN TO REPAIR OR REPLACE ANY COMPONENT THAT IS DAMAGED OR OTHERWISE DEFICIENT.
15. THE OWNER SHALL MAINTAIN THE STRUCTURAL INTEGRITY OF THE RACK SYSTEM BY ASSURING PROPER OPERATIONAL, HOUSE KEEPING AND MAINTENANCE PROCEDURES, BUT NOT LIMITED TO THE FOLLOWING:
- A. PROHIBIT ANY OVER LOADING OF ANY PALLET POSITIONS AND OF OVERALL RACK SYSTEMS.
- B. REGULARLY INSPECT FOR DAMAGE; IF DAMAGE IS FOUND, IMMEDIATELY UNLOAD THE AFFECTED AREA AND REPLACE OR REPAIR ANY DAMAGED COLUMNS, BEAMS, OR OTHER STRUCTURAL COMPONENTS.
- C. REQUIRE ALL PALLETS TO BE MAINTAINED IN GOOD, SAFE, OPERATING CONDITION.
- D. ENSURE THAT PALLETS ARE PROPERLY PLACED ONTO PALLET LOAD SUPPORT MEMBERS IN PROPERLY STACKED AND STABLE POSITION.
- E. REQUIRE THAT ALL GOODS STORED ON EACH PALLET TO BE PROPERLY STACKED AND STABLE.
- F. PROHIBIT DOUBLE STACKING OF ANY PALLET POSITION, INCLUDING THE TOP MOST POSITION
- G. THE OWNER AND/OR USER OF THE RACK SYSTEM MUST PROVIDE MEASURES TO MITIGATE DAMAGE TO THE STORAGE RACK BY USE OF IMPACT PROTECTIVE DEVICES IN AREAS WHERE FORKLUFT AND/OR HEAVY MACHINERY ARE IN USE.
- H. ENSURE THAT THE RACKS ARE NOT MODIFIED OR REARRANGED IN A MANNER NOT WITHIN THE ORIGINAL DESIGN CONFIGURATION.



Structural Engineering & Design, Inc.

1815 Wright Ave
La Verne, CA 91750
Phone: 909.596.1351 Fax: 909.596.7186

Project Name : BUTLER SUPPLY

Project Number : 25-0625-3

Date : 07/01/25

Street Address: 2736 NE MCBAINE DR
City/State : LEES SUMMIT, MO 64064

Scope of Work : STORAGE RACK



Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

TABLE OF CONTENTS

Title Page	1
Table of Contents.....	2
Design Data and Definition of Components	3
Critical Configuration	4
Seismic Loads	5 to 6
Column	7
Beam and Connector	8 to 9
Bracing	10
Anchors	11
Base Plate	12
Slab on Grade	13
Other Configurations	14 to 24

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Design Data

1) The analyses herein conforms to the requirements of the:
2021 IBC Section 2209

ANSI MH 16.1-2012 Specifications for the Design of Industrial Steel Storage Racks "2012 RMI Rack Design Manual"
ASCE 7-16, section 15.5.3

2) Transverse braced frame steel conforms to ASTM A570, Gr.55, with minimum strength, $F_y=55$ ksi
Longitudinal frame beam and connector steel conforms to ASTM A570, Gr.55, with minimum yield, $F_y=55$ ksi
All other steel conforms to ASTM A36, Gr. 36 with minimum yield, $F_y= 36$ ksi


3) Anchor bolts shall be provided by installer per ICC reference on plans and calculations herein.

4) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.


5) The existing slab on grade is 6" thick with minimum 4000 psi compressive strength. Allowable Soil bearing capacity is 750 psf. The design of the existing slab is by others.

6) Load combinations for rack components correspond to 2012 RMI Section 2.1 for ASD level load criteria

Definition of Components



Front View: Down Aisle
(Longitudinal) Frame



Section A: Cross Aisle
(Transverse) Frame

Structural Engineering & Design Inc.


1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Configuration & Summary: TYPE 1 SELECTIVE RACK



****RACK COLUMN REACTIONS**
UNFACTORED LOAD
 AXIAL D= 75 lb
 AXIAL P= 4,500 lb
 AXIAL S= lb
SEISMIC AXIAL Ps= +/- 441 lb
BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	3	42 in	216.0 in	3	96 in	Single Row

Component		Description							STRESS
Column	Fy=55 ksi	Mecalux 314 3.0"x2.69"x0.070"			P=4575 lb, M=4415 in-lb			0.85-OK	
Column & Backer	None	None			None			N/A	
Beam	Fy=55 ksi	Intlk 40E 4Hx2.75Wx0.059"Thk			Lu=96 in	Capacity: 5164 lb/pr		0.58-OK	
Beam Connector	Fy=55 ksi	Lvl 1: 3 Tab OK	Mconn=3521 in-lb			Mcap=8828 in-lb		0.4-OK	
Brace-Horizontal	Fy=50 ksi	Mclx C456 Sgl 1.7953x1.378x16ga(U31x)						0.04-OK	
Brace-Diagonal	Fy=50 ksi	Mclx C456 Sgl 1.7953x1.378x16ga(U31x)						0.39-OK	
Base Plate	Fy=36 ksi	5.09x4.66x0.194				Fixity= 0 in-lb		0.52-OK	
Anchor	1 per Base	0.5" x 3.25" Embed HILTI TZ2 ESR 4266 Inspection Req'd (Net Seismic Uplift=0 lb)						0.025-OK	
Slab & Soil	6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.27-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector
1	3,000 lb	84.0 in	32.0 in	31 lb	21 lb	4,575 lb	4,415 "#	3,521 "#	3 Tab OK
2	3,000 lb	60.0 in	64.0 in	53 lb	35 lb	3,050 lb	1,326 "#	2,310 "#	3 Tab OK
3	3,000 lb	72.0 in	90.0 in	79 lb	53 lb	1,525 lb	954 "#	1,846 "#	3 Tab OK

** Load defined as product weight per pair of beams Total: 163 lb 109 lb

Notes

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Seismic Forces Configuration: TYPE 1 SELECTIVE RACK

Lateral analysis is performed with regard to the requirements of the 2012 RMI ANSI MH 16.1-2012 Sec 2.6 & ASCE 7-16 sec 15.5.3

Transverse (Cross Aisle) Seismic Load

$$V = Cs * Ip * Ws = Cs * Ip * (0.67 * P * Rf + D + 0.2S)$$

$$Cs1 = Sds / R$$

$$= 0.0264$$

$$Cs2 = 0.044 * Sds$$

$$= 0.0046$$

$$Cs3 = 0.5 * S1 / R$$

$$= 0.0085$$

$$Cs-max = 0.0264$$

$$\text{Base Shear Coeff} = Cs = 0.0264$$

$$Cs-max * Ip = 0.0264$$

$$V_{min} = 0.015$$

$$\text{Eff Base Shear} = Cs = 0.0264$$


$$Ws = (0.67 * PL_{RF1} * PL) + DL + 0.2S$$

$$= 6,180 \text{ lb}$$

$$V_{transv} = V_t = 0.0264 * (150 \text{ lb} + 6030 \text{ lb} + 0.2)$$

$$E_{transverse} = 163 \text{ lb}$$

Limit States Level Transverse seismic shear per upright



Transverse Elevation

(Transverse, Braced Frame Dir.) R= 4.0

$$Ss = 0.099$$

$$S1 = 0.068$$

$$Fa = 1.600$$

$$Fv = 2.400$$

$$Sds = 2/3 * Ss * Fa = 0.106$$

$$Sd1 = 2/3 * S1 * Fv = 0.109$$

$$Ip = 1.0$$

$$P_{RF1} = 1.0$$

$$\text{Pallet Height} = hp = 0.0 \text{ in}$$

$$DL \text{ per Beam Lvl} = 50 \text{ lb}$$

Level	PRODUCT LOAD P	P*0.67*P _{RF1}	DL	hi	wi*hi	Fi	Fi*(hi+hp/2)
1	3,000 lb	2,010 lb	50 lb	84 in	173,040	30.8 lb	2,587-#
2	3,000 lb	2,010 lb	50 lb	144 in	296,640	52.9 lb	7,618-#
3	3,000 lb	2,010 lb	50 lb	216 in	444,960	79.3 lb	17,129-#
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
			0 lb		0		
sum:	P=9000 lb	6,030 lb	150 lb	W=6180 lb	914,640	163 lb	Σ=27,334

Longitudinal (Downaisle) Seismic Load

Similarly for longitudinal seismic loads, using R=6.0

$$Ws = (0.67 * PL_{RF2} * P) + DL + 0.2S$$

$$= 6,180 \text{ lb}$$

(Longitudinal, Unbraced Dir.) R= 6.0

$$Cs1 = 0.0176$$

$$Cs2 = 0.0046$$

$$Cs3 = 0.0057$$

$$Cs-max = 0.0176$$

$$Cs = Cs-max * Ip = 0.0176$$


$$P_{RF2} = 1.0$$

$$T = 0.75 \text{ sec}$$

$$V_{long} = 0.0176 * (150 \text{ lb} + 6030 \text{ lb} + 0.2 * 0)$$

$$E_{longitudinal} = 109 \text{ lb}$$

Limit States Level Longit. seismic shear per upright



Front View

Level	PRODUC LOAD P	P*0.67*P _{RF2}	DL	hi	wi*hi	Fi
1	3,000 lb	2,010 lb	50 lb	84 in	173,040	20.6 lb
2	3,000 lb	2,010 lb	50 lb	144 in	296,640	35.4 lb
3	3,000 lb	2,010 lb	50 lb	216 in	444,960	53.0 lb
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
					0	
sum:		6,030 lb	150 lb	W=6180 lb	914,640	109 lb

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3


Downaisle Seismic Loads

Configuration: TYPE 1 SELECTIVE RACK

Determine the story moments by applying portal analysis. The base plate is assumed to provide no fixity.

Seismic Story Forces

$$\begin{aligned} V_{long} &= 109 \text{ lb} \\ V_{col} &= V_{long}/2 = 55 \text{ lb} \\ F1 &= 21 \text{ lb} \\ F2 &= 35 \text{ lb} \\ F3 &= 53 \text{ lb} \end{aligned}$$



Seismic Story Moments


Conceptual System

COI

$$\begin{aligned} M_{base-max} &= 0 \text{ in-lb} <==== \text{Default capacity} \\ M_{base-v} &= (V_{col} * h1_{eff})/2 \\ &= 2,207 \text{ in-lb} <==== \text{Moment going to base} \\ M_{base-eff} &= \text{Minimum of } M_{base-max} \text{ and } M_{base-v} \\ &= 0 \text{ in-lb} \text{ PINNED BASE ASSUMED} \\ M1-1 &= [V_{col} * h1_{eff}] - M_{base-eff} \\ &= (55 \text{ lb} * 81 \text{ in}) - 0 \text{ in-lb} \\ &= 4,415 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} h1_{eff} &= h1 - \text{beam clip height}/2 \\ &= 81 \text{ in} \end{aligned}$$

$$\begin{aligned} M2-2 &= [V_{col} - (F1)/2] * h2 \\ &= [55 \text{ lb} - 17.7 \text{ lb}] * 60 \text{ in}/2 \\ &= 1,326 \text{ in-lb} \end{aligned}$$



Beam to Column Elevation

$$M_{seis} = (M_{upper} + M_{lower})/2$$

$$\begin{aligned} M_{seis}(1-1) &= (4415 \text{ in-lb} + 1326 \text{ in-lb})/2 \\ &= 2,870 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} M_{seis}(2-2) &= (1326 \text{ in-lb} + 954 \text{ in-lb})/2 \\ &= 1,140 \text{ in-lb} \end{aligned}$$

$$\rho = 1.0000$$

Summary of Forces

LEVEL	hi	Axial Load	Column Moment**	Mseismic**	Mend-fixity	Mconn**	Beam Connector
1	84 in	4,575 lb	4,415 in-lb	2,870 in-lb	2,160 in-lb	3,521 in-lb	3 Tab OK
2	60 in	3,050 lb	1,326 in-lb	1,140 in-lb	2,160 in-lb	2,310 in-lb	3 Tab OK
3	72 in	1,525 lb	954 in-lb	477 in-lb	2,160 in-lb	1,846 in-lb	3 Tab OK

$$M_{conn} = (M_{seismic} + M_{end-fixity}) * 0.70 * \rho$$

$$M_{conn-allow}(3 \text{ Pin}) = 8,828 \text{ in-lb}$$

**all moments based on limit states level loading

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Column (Longitudinal Loads) Configuration: TYPE 1 SELECTIVE RACK

Section Properties

Section: Mecalux 314 3.0"x2.69"x0.070"

Aeff = 0.538 in²

Ix = 0.765 in⁴

Sx = 0.510 in³

rx = 1.190 in

Ωf = 1.67

E = 29,500 ksi

Iy = 0.464 in⁴

Sy = 0.307 in³

ry = 0.928 in

Fy = 55 ksi

Cmx = 0.85


Kx = 1.7

Lx = 82.0 in

Ky = 1.0

Ly = 32.0 in

Cb = 1.0



Loads Considers loads at level 1

COLUMN DL = 75 lb

COLUMN PL = 4,500 lb

Mcol = 4,414 in-lb

Sds = 0.1056

1+0.105*Sds = 1.0111

1.4+0.14Sds = 1.4148

1+0.14Sds = 1.0148

0.85+0.14*Sds = 0.8648

B = 0.7000

rho = 1.0000

Critical load cases are: RMI Sec 2.1

Load Case 5: : $(1+0.105*Sds)D + 0.75*(1.4+0.14Sds)*B*P + 0.75*(0.7*\rho*E) \leq 1.0$, ASD Method

axial load coeff: 0.7427616 * P

seismic moment coeff: 0.5625 * Mcol

Load Case 6: : $(1+0.104*Sds)D + (0.85+0.14Sds)*B*P + (0.7*\rho*E) \leq 1.0$, ASD Method

axial load coeff: 0.60535

seismic moment coeff: 0.7 * Mcol

By analysis, Load case 5 governs utilizing loads as such

Axial Load=Pax= $1.011088*75 \text{ lb} + 0.75 * 1.414784 * 0.7 * 4500 \text{ lb}$

= 3,418 lb

Moment=Mx= $0.75*0.7*\rho*Mcol$

= 0.525*4414 in-lb

= 2,317 in-lb

Axial Analysis

KxLx/rx = $1.7*82/1.19$

= 117.1

KyLy/ry = $1*32/0.9284$

= 34.5

Fe < Fy/2

Fn = Fe

= $\pi^2 E / (KL/r)_{\max}^2$

= 21.2 ksi

Pa = Pn/Ωc

= 11413 lb/1.92

= 5,944 lb

Fe = $\pi^2 E / (KL/r)_{\max}^2$

= 21.2ksi

Pn = Aeff*Fn

= 11,413 lb

P/Pa = 0.58

> 0.15

Fy/2 = 27.5 ksi

Ωc = 1.92

Bending Analysis

Check: $Pax/Pa + (Cmx*Mx)/(Max*\mu_x) \leq 1.0$

$P/Pao + Mx/Max \leq 1.0$

Pno = Ae*Fy

= $0.538 \text{ in}^2 * 55000 \text{ psi}$

= 29,585 lb

Pao = Pno/Ωc

= $29585 \text{ lb} / 1.92$

= 15,409 lb

Myield = My = Sx*Fy

= $0.51 \text{ in}^3 * 55000 \text{ psi}$

= 28,050 in-lb

Max = My/Ωf

= $28050 \text{ in-lb} / 1.67$

= 16,796 in-lb

$\mu_x = \{1/[1-(\Omega_c*P/Pcr)]\}^{-1}$

= $\{1/[1-(1.92*3418 \text{ lb}/11462 \text{ lb})]\}^{-1}$

= 0.43

Pcr = $\pi^2 EI / (KL)_{\max}^2$

= $\pi^2 * 29500 \text{ ksi} / (1.7*82 \text{ in})^2$

= 11,462 lb

Combined Stresses

$(3418 \text{ lb} / 5944 \text{ lb}) + (0.85*2317 \text{ in-lb}) / (16796 \text{ in-lb}*0.43) =$

0.85

< 1.0, OK

(EQ C5-1)

$(3418 \text{ lb} / 15409 \text{ lb}) + (2317 \text{ in-lb} / 16796 \text{ in-lb}) =$

0.36

< 1.0, OK

(EQ C5-2)

** For comparison, total column stress computed for load case 6 is: 77.0%

izing loads 2800.1784 lb Axial and M= 3089 in-lb

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: **Bob S**

Project: **Butler Supply**

Project #: **25-0625-3**

BEAM

Configuration: TYPE 1 SELECTIVE RACK


DETERMINE ALLOWABLE MOMENT CAPACITY

A) Check compression flange for local buckling (B2.1)

$$\begin{aligned} w &= c - 2*t - 2*r \\ &= 1.75 \text{ in} - 2*0.059 \text{ in} - 2*0.059 \text{ in} \\ &= 1.514 \text{ in} \\ w/t &= 25.66 \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (F_y/E)^{0.5} \\ &= [1.052/(4)^{0.5}] * 25.66 * (55/29500)^{0.5} \\ &= 0.583 < 0.673, \text{ Flange is fully effective} \end{aligned}$$

Eq. B2.1-4

Eq. B2.1-1



B) check web for local buckling per section b2.3

$$\begin{aligned} f_1(\text{comp}) &= F_y * (y_3/y_2) = 50.23 \text{ ksi} \\ f_2(\text{tension}) &= F_y * (y_1/y_2) = 101.99 \text{ ksi} \\ Y &= f_2/f_1 \\ &= -2.03 \\ k &= 4 + 2*(1-Y)^3 + 2*(1-Y) \\ &= 65.70 \\ \text{flat depth} &= w = y_1 + y_3 \\ &= 3.764 \text{ in} \quad w/t = 63.79661017 \quad \text{OK} \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (f_1/E)^{0.5} \\ &= [1.052/(65.7)^{0.5}] * 3.764 * (50.23/29500)^{0.5} \\ &= 0.342 < 0.673 \\ b_e &= w = 3.764 \text{ in} \quad b_2 = b_e/2 \\ &= 1.88 \text{ in} \\ b_1 &= b_e(3-Y) \\ &= 0.748 \\ b_1 + b_2 &= 2.628 \text{ in} > 1.242 \text{ in, Web is fully effective} \end{aligned}$$

Eq. B2.3-5

Eq. B2.3-4

OK

Eq B2.3-2

Beam= **Intlik 40E 4Hx2.75Wx0.059"Thk**

I_x	1.667 in^4
S_x	0.783 in^3
Y_{cg}	2.640 in
t	0.059 in
Bend Radius= r	0.059 in
$F_y = F_{yv}$	55.00 ksi
$F_u = F_{uv}$	65.00 ksi
E	29500 ksi
top flange= b	1.750 in
bottom flange= b	2.750 in
Web depth= d	4.000 in

Determine effect of cold working on steel yield point (F_{ya}) per section A7.2

$$\begin{aligned} F_{ya} &= C * F_{yc} + (1-C) * F_y \quad (\text{EQ A7.2-1}) \\ L_{corner} &= L_c = (p/2) * (r + t/2) \\ &= 0.139 \text{ in} \quad C = 2 * L_c / (L_f + 2 * L_c) \\ L_{flange-top} &= L_f = 1.514 \text{ in} \quad = 0.155 \text{ in} \\ m &= 0.192 * (F_u/F_y) - 0.068 \quad (\text{EQ A7.2-4}) \\ &= 0.1590 \\ B_c &= 3.69 * (F_u/F_y) - 0.819 * (F_u/F_y)^2 - 1.79 \\ &= 1.427 \\ \text{since } f_u/F_v &= 1.18 < 1.2 \\ \text{and } r/t &= 1 < 7 \text{ OK} \\ \text{then } F_{yc} &= B_c * F_y / (R/t)^m \quad (\text{EQ A7.2-2}) \\ &= 78.485 \text{ ksi} \end{aligned}$$

$$\begin{aligned} \text{Thus, } F_{ya-top} &= 58.64 \text{ ksi} \quad (\text{tension stress at top}) \\ F_{ya-bottom} &= F_{ya} * Y_{cg} / (\text{depth} - Y_{cg}) \\ &= 113.84 \text{ ksi} \quad (\text{tension stress at bottom}) \end{aligned}$$

Check allowable tension stress for bottom flange


$$\begin{aligned} L_{flange-bot} &= L_{fb} = L_{bottom} - 2 * r - 2 * t \\ &= 2.514 \text{ in} \\ C_{bottom} &= C_b = 2 * L_c / (L_{fb} + 2 * L_c) \\ &= 0.100 \end{aligned}$$

$$\begin{aligned} F_{y-bottom} &= F_{yb} = C_b * F_{yc} + (1-C_b) * F_y \\ &= 57.34 \text{ ksi} \end{aligned}$$

$$\begin{aligned} F_{ya} &= (F_{ya-top}) * (F_{yb} / F_{ya-bottom}) \\ &= 29.54 \text{ ksi} \end{aligned}$$

$$\text{if } F = 0.95$$

$$\text{Then } F * M_n = F * F_{ya} * S_x = 21.96 \text{ in-k}$$



$$\begin{aligned} y_1 &= Y_{cg} - t - r = 2.522 \text{ in} \\ y_2 &= \text{depth} - Y_{cg} = 1.360 \text{ in} \\ y_3 &= y_2 - t - r = 1.242 \text{ in} \end{aligned}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: **Bob S**

Project: **Butler Supply**

Project #: **25-0625-3**

BEAM

Configuration: TYPE 1 SELECTIVE RACK

RMI Section 5.2, PT II

Section

Beam= Intlk 40E 4Hx2.75Wx0.059"Thk

$I_x = I_y = 1.667 \text{ in}^4$

$S_x = 0.783 \text{ in}^3$

$t = 0.059 \text{ in}$

$E = 29500 \text{ ksi}$

$F = 225.0$

$F_y = F_{yv} = 55 \text{ ksi}$

$L = 96 \text{ in}$


$F_u = F_{uv} = 65 \text{ ksi}$

$F_{ya} = 58.6 \text{ ksi}$

Beam Level= 1

$P = \text{Product Load} = 3,000 \text{ lb/pair}$

$D = \text{Dead Load} = 50 \text{ lb/pair}$



1. Check Bending Stress Allowable Loads

$$M_{center} = F \cdot Mn = W \cdot L \cdot W \cdot R_m / 8$$

W=LRFD Load Factor= $1.2 \cdot D + 1.4 \cdot P + 1.4 \cdot (0.125) \cdot P$
FOR DL=2% of PL,

RMI 2.2, item 8

$$W = 1.599$$

$$R_m = 1 - [(2 \cdot F \cdot L) / (6 \cdot E \cdot I_b + 3 \cdot F \cdot L)]$$

$$= 1 - (2 \cdot 225 \cdot 96 \text{ in}) / [(6 \cdot 29500 \text{ ksi} \cdot 1.667 \text{ in}^4) + (3 \cdot 225 \cdot 96 \text{ in})]$$

$$= 0.88$$

$$\text{if } F = 0.95$$

$$\text{Then } F \cdot Mn = F \cdot F_{ya} \cdot S_x = 43.59 \text{ in-k}$$

Thus, allowable load

$$\text{per beam pair} = W = F \cdot Mn \cdot 8 \cdot (\# \text{ of beams}) / (L \cdot R_m \cdot W)$$

$$= 43.59 \text{ in-k} \cdot 8 \cdot 2 / (96 \text{ in} \cdot 0.88 \cdot 1.599)$$


$$= \mathbf{5,164 \text{ lb/pair} \quad \text{allowable load based on bending stress}}$$

$$M_{end} = W \cdot L \cdot (1 - R_m) / 8$$

$$= (5164 \text{ lb/2}) \cdot 96 \text{ in} \cdot (1 - 0.88) / 8$$

$$= 3,718 \text{ in-lb} \quad @ \text{ 5164 lb max allowable load}$$

$$= 2,160 \text{ in-lb} \quad @ \mathbf{3000 \text{ lb imposed product load}}$$



2. Check Deflection Stress Allowable Loads

$$D_{max} = D_{ss} \cdot R_d$$

$$R_d = 1 - (4 \cdot F \cdot L) / (5 \cdot F \cdot L + 10 \cdot E \cdot I_b)$$

$$= 1 - (4 \cdot 225 \cdot 96 \text{ in}) / (5 \cdot 225 \cdot 96 \text{ in} + (10 \cdot 29500 \text{ ksi} \cdot 1.667 \text{ in}^4))$$

$$= 0.856 \text{ in}$$

if $D_{max} = L/180$ *Based on L/180 Deflection Criteria*

$$\text{and } D_{ss} = 5 \cdot W \cdot L^3 / (384 \cdot E \cdot I_b)$$

$$\text{Allowable Deflection} = L/180$$

$$= 0.533 \text{ in}$$

$$\text{Deflection at imposed Load} = 0.310 \text{ in}$$

$$L/180 = 5 \cdot W \cdot L^3 \cdot R_d / (384 \cdot E \cdot I_b \cdot \# \text{ of beams})$$

solving for W yields,

$$W = 384 \cdot E \cdot I_b \cdot 2 / (180 \cdot 5 \cdot L^2 \cdot R_d)$$

$$= 384 \cdot 1.667 \text{ in}^4 \cdot 2 / [180 \cdot 5 \cdot (96 \text{ in})^2 \cdot 0.856]$$

$$= \mathbf{5,319 \text{ lb/pair} \quad \text{allowable load based on deflection limits}}$$

Thus, based on the least capacity of item 1 and 2 above:

Allowable load= 5,164 lb/pair
Imposed Product Load= 3,000 lb/pair

Beam Stress= 0.58

Beam at Level 1

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: **Bob S**

Project: **Butler Supply**


Project #: **25-0625-3**

3 Tab Beam to Column Connection

Configuration: TYPE 1 SELECTIVE RACK

$$\begin{aligned} M_{conn \max} &= (M_{seismic} + M_{end-fixity}) * 0.70 * \rho \\ &= 3,521 \text{ in-lb} \quad \text{Load at level 1} \end{aligned}$$

Connector Type= 3 Tab



Shear Capacity of Tab

Tab Length= 0.50 in

Fy= 55,000 psi

$$\begin{aligned} A_{shear} &= 0.5 \text{ in} * 0.135 \text{ in} \\ &= 0.0675 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} P_{shear} &= 0.4 * F_y * A_{shear} \\ &= 0.4 * 55000 \text{ psi} * 0.0675 \text{ in}^2 \\ &= 1,485 \text{ lb} \end{aligned}$$

Bearing Capacity of Tab

tcol= 0.070 in

Fu= 65,000 psi

Bearing Length= 0.5000 in

Omega= 2.22

a= 2.22

$$\begin{aligned} P_{bearing} &= \alpha * F_u * \text{tab length} * t_{col} / \Omega \\ &= 2.22 * 65000 \text{ psi} * 0.5 \text{ in} * 0.07 \text{ in} / 2.22 \\ &= 2,275 \text{ lb} > 1485 \text{ lb} \end{aligned}$$

Moment Capacity of Bracket

Edge Distance=E= 1.00 in

Tab Spacing= 2.0 in

Fy= 55,000 psi

$$\begin{aligned} C &= P1 + P2 + P3 \\ &= P1 + P1 * (2.5 / 4.5) + P1 * (0.5 / 4.5) \\ &= 1.667 * P1 \end{aligned}$$

tclip= 0.135 in

Sclip= 0.183 in³

$$\begin{aligned} M_{cap} &= S_{clip} * F_{bending} \\ &= 0.1832 \text{ in}^3 * 0.66 * F_y \\ &= 6,650 \text{ in-lb} \end{aligned}$$

C*d= Mcap = 1.667

$$\begin{aligned} d &= E / 2 \\ &= 0.50 \text{ in} \end{aligned}$$

$$\begin{aligned} P_{clip} &= M_{cap} / (1.667 * d) \\ &= 6650.16 \text{ in-lb} / (1.667 * 0.5 \text{ in}) \\ &= 7,979 \text{ lb} \end{aligned}$$

Thus, P1= 1,485 lb

$$\begin{aligned} M_{conn-allow} &= [P1 * 4.5 + P1 * (2.5 / 4.5) * 2.5 + P1 * (0.5 / 4.5) * 0.5] \\ &= 1485 \text{ LB} * [4.5 + (2.5 / 4.5) * 2.5 + (0.5 / 4.5) * 0.5] \\ &= 8,828 \text{ in-lb} > M_{conn \max}, \text{ OK} \end{aligned}$$

Stress= 0.4

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Transverse Brace

Configuration: TYPE 1 SELECTIVE RACK

Section Properties

Diagonal Member= Mclx C456 Sgl 1.7953x1.378x16ga(U31x)


Area= 0.259 in²

r min= 0.449 in

Fy= 50,000 psi

K= 1.0

Ωc= 1.92




Horizontal Member= Mclx C456 Sgl 1.7953x1.378x16ga(U31x)

Area= 0.259 in²

r min= 0.449 in

Fy= 50,000 psi

K= 1.0



Frame Dimensions

Bottom Panel Height=H= 90.0 in

Frame Depth=D= 42.0 in

Column Width=B= 2.7 in

Clear Depth=D-B*2= 36.6 in

X Brace= NO

rho= 1.30

Diagonal Member

Load Case 6: : $(1+0.104Sds)D + [(0.85+0.14Sds)*B*P + [0.7*rho*E] <= 1.0$, ASD Method

Vtransverse= 163 lb

Vb=Vtransv*0.7*rho= 163 lb * 0.7 * 1.3

= 148 lb

Ldiag= [(D-B*2)^2 + (H-6")^2]^1/2

= 91.6 in

Pmax= V*(Ldiag/D)

= 371 lb

axial load on diagonal brace member

Pn= AREA*Fn

= 0.259 in² * 6996 psi

= 1,810 lb

Pallow= Pn/Ω

= 1810 lb /1.92


= 943 lb

Pn/Pallow= 0.39 <= 1.0 OK

(kl/r)= (k * Ldiag)/r min
= (1 x 91.6 in /0.449 in)
= 204.0 in
Fe= pi^2*E/(kl/r)^2
= 6,996 psi

Since Fe<Fy/2,

Fn= Fe
= 6,996 psi



Horizontal brace

Vb=Vtransv*0.7*rho= 148 lb

(kl/r)= (k * Lhoriz)/r min
= (1 x 42 in) /0.449 in
= 93.5 in

Since Fe>Fy/2, Fn=Fy*(1-fy/4fe)

= 31,233 psi

Fe= pi^2*E/(kl/r)^2
= 33,304 psi

Pn= AREA*Fn

= 0.259in²*31233 psi

= 8,080 lb

Fy/2= 25,000 psi

Pallow= Pn/Ωc

= 8080 lb /1.92

= 4,208 lb

Pn/Pallow= 0.04 <= 1.0 OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Single Row Frame Overturning

Configuration: TYPE 1 SELECTIVE RACK

Loads

Critical Load case(s):

1) RMI Sec 2.2, Item 7: $(0.9-0.2Sds)D + (0.9-0.20Sds)*B*\rho - E*\rho$

$$V_{trans}=V=E=Q_e= 163 \text{ lb}$$

$$\text{DEAD LOAD PER UPRIGHT}=D= 150 \text{ lb}$$

$$\text{PRODUCT LOAD PER UPRIGHT}=P= 9,000 \text{ lb}$$

$$P_{app}=P*0.67= 6,030 \text{ lb}$$

$$W_{st} \text{ LC1}=W_{st1}=(0.87888*D + 0.87888*P_{app}*1)= 5,431 \text{ lb}$$

$$\text{Product Load Top Level, } P_{top}= 3,000 \text{ lb}$$

$$DL/Lvl= 50 \text{ lb}$$

$$\text{Seismic Ovt based on E, } \Sigma(F_i*h_i)= 18,546 \text{ in-lb}$$

$$\text{height/depth ratio}= 5.1 \text{ in}$$

$$S_{ds}= 0.1056$$

$$(0.9-0.2S_{ds})= 0.8789$$

$$(0.9-0.2S_{ds})= 0.8789$$

$$B= 1.0000$$

$$\rho= 1.0000$$


$$\text{Frame Depth}=D_f= 42.0 \text{ in}$$

$$H_{top-lvl}=H= 216.0 \text{ in}$$

$$\# \text{ Levels}= 3$$

$$\# \text{ Anchors/Base}= 1$$

$$h_p= .0 \text{ in}$$



SIDE ELEVATION

A) Fully Loaded Rack

$$h=H+h_p/2= 216.0 \text{ in}$$

Load case 1:

$$\begin{aligned} \text{Movt} &= \Sigma(F_i*h_i)*E*\rho \\ &= 18,546 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} \text{Mst} &= W_{st1} * D_f/2 \\ &= 5431 \text{ lb} * 42 \text{ in}/2 \\ &= 114,051 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} T &= (\text{Movt}-\text{Mst})/D_f \\ &= (18546 \text{ in-lb} - 114051 \text{ in-lb})/42 \text{ in} \\ &= -2,274 \text{ lb} \end{aligned}$$

No Uplift

$$\text{Net Seismic Uplift}= -4,548 \text{ lb}$$

Strength Level

B) Top Level Loaded Only

Load case 1:

$$\begin{aligned} \square V_1 &= V_{top}= C_s * I_p * P_{top} \geq 350 \text{ lb for } H/D > 6.0 \\ &= 0.0264 * 3000 \text{ lb} \\ &= 79 \text{ lb} \end{aligned}$$

$$V_{1eff}= 79 \text{ lb}$$

$$\begin{aligned} V_2 &= V_{dl}= C_s * I_p * D \\ &= 4 \text{ lb} \end{aligned}$$

$$\begin{aligned} \text{Mst} &= (0.87888*D + 0.87888*P_{top}*1) * 42 \text{ in}/2 \\ &= 58,138 \text{ in-lb} \end{aligned}$$

$$\text{Critical Level}= 3$$

$$C_s * I_p= 0.0264$$

$$\begin{aligned} \text{Movt} &= [V_1*h + V_2 * H/2]*\rho \\ &= 17,535 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} T &= (\text{Movt}-\text{Mst})/D_f \\ &= (17535 \text{ in-lb} - 58138 \text{ in-lb})/42 \text{ in} \\ &= -967 \text{ lb} \end{aligned}$$

No Uplift

$$\text{Net Seismic Uplift}= -1,934 \text{ lb}$$

Strength Level

Anchor

Check (1) 0.5" x 3.25" Embed HILTI TZ2 anchor(s) per base plate.

Special inspection is required per ESR 4266.

$$\text{Pullout Capacity}=T_{cap}= 1,961 \text{ lb}$$

$$\text{Shear Capacity}=V_{cap}= 2,517 \text{ lb}$$

$$\text{L.A. City Jurisdiction? NO}$$

$$\Phi= 1$$

$$T_{cap}*\Phi= 1,961 \text{ lb}$$

$$V_{cap}*\Phi= 2,517 \text{ lb}$$

Fully Loaded:

$$(81 \text{ lb}/2517 \text{ lb})^{\wedge}1 = 0.03$$

$$\leq 1.2 \text{ OK}$$

Top Level Loaded:

$$(-1934 \text{ lb}/1961 \text{ lb})^{\wedge}1 + (39 \text{ lb}/2517 \text{ lb})^{\wedge}1 = 0.02$$

$$\leq 1.2 \text{ OK}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3


Base Plate

Configuration: TYPE 1 SELECTIVE RACK

Section

Baseplate= 5.09x4.66x0.194
Eff Width=W = 5.09 in
Eff Depth=D = 4.66 in
Column Width=b = 3.00 in
Column Depth=dc = 2.69 in
L = 1.05 in
Plate Thickness=t = 0.194 in

a = 1.55 in
Anchor c.c. = 2*a = d = 3.09 in
N=# Anchor/Base= 1
Fy = 36,000 psi
rho = 1



Downaisle Elevation

Down Aisle Loads Load Case 5: $(1+0.105*Sds)D + 0.75*[(1.4+0.14Sds)*B*P + 0.75*[0.7*rho*E] \leq 1.0, ASD Method$

COLUMN DL= 75 lb
COLUMN PL= 4,500 lb
Base Moment= 0 in-lb

Axial=P= 1.011088 * 75 lb + 0.75 * (1.414784 * 0.7 * 4500 lb)
= 3,418 lb

$1+0.105*Sds = 1.0111$
 $1.4+0.14Sds = 1.4148$
B= 0.7000

Mb= Base Moment*0.75*0.7*rho
= 0 in-lb * 0.75*0.7*rho
= 0 in-lb

Axial Load P = 3,418 lb **Mbase=Mb = 0 in-lb**

Axial stress=fa = P/A = P/(D*W)
= 144 psi

M1= wL^2/2= fa*L^2/2
= 79 in-lb

Moment Stress=fb = M/S = 6*Mb/[(D*B^2)]
= 0.0 psi

Moment Stress=fb2 = 2 * fb * L/W
= 0.0 psi

Moment Stress=fb1 = fb-fb2
= 0.0 psi

M2= fb1*L^2/2
= 0 in-lb

M3 = (1/2)*fb2*L*(2/3)*L = (1/3)*fb2*L^2
= 0 in-lb

Mtotal = M1+M2+M3
= 79 in-lb/in

S-plate = (1)(t^2)/6
= 0.006 in^3/in

Fb = 0.75*Fy
= 27,000 psi

fb/Fb = Mtotal/[(S-plate)(Fb)]
= **0.46** **OK**

Fp = 0.7*F'c
= 2,800 psi

Tanchor = (Mb-(PLapp*0.75*0.46)(a))/[(d)*N/2]
= -5,431 lb No Tension

Tallow = 1,961 lb **OK**

Cross Aisle Loads Critical load case RMI Sec 2.1, Item 4: $(1+0.11Sds)DL + (1+0.14Sds)PL*0.75+EL*0.75 \leq 1.0, ASD Method$

Pstatic= 3,418 lb

Movt*0.75*0.7*rho = 18,655 in-lb
Frame Depth= 42.0 in

Pseismic= Movt/Frame Depth
= 444 lb

P=Pstatic+Pseismic= 3,862 lb

b = Column Depth= 2.69 in

L = Base Plate Depth-Col Depth= 1.05 in

fa = P/A = P/(D*W)
= 163 psi

M= wL^2/2= fa*L^2/2
= 89 in-lb/in


Sbase/in = (1)(t^2)/6
= 0.006 in^3/in

Fbase = 0.75*Fy
= 27,000 psi

fb/Fb = M/[(S-plate)(Fb)]
= **0.52** **OK**

Check uplift load on Baseplate

Check uplift forces on baseplate with 2 or more anchors per RMI 7.2.2.
"When the base plate configuration consists of two anchor bolts located on either side of the column and a net uplift force exists, the minimum base plate thickness shall be determined based on a design bending moment in the plate equal to the uplift force on one anchor times 1/2 the distance from the centerline of the anchor to the nearest edge of the rack column"



Elevation

Uplift per Column= 0 lb

Qty Anchor per BP= 1

Net Tension per anchor=Ta= 0 lb

c= 1.05 in

Mu=Moment on Baseplate due to uplift= Ta*c/2
= in-lb

Splate= 0.029 in^3

[fb/Fb]*0.75= 0

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Bob S

Project: Butler Supply


Project #: 25-0625-3

Slab on Grade

Configuration: TYPE 1 SELECTIVE RACK



SLAB ELEVATION



Baseplate Plan View

Concrete

$f'_c = 4,000$ psi

$t_{slab} = t = 6.0$ in

$t_{eff} = 6.0$ in

$\phi = 0.6$

Soil

$f_{soil} = 750$ psf

$Movt = 18,546$ in-lb

Frame depth = 42.0 in

$Sds = 0.106$

$0.2 \cdot Sds = 0.021$

$\lambda = 0.600$

$\beta = B/D = 1.092$

$F'_c^{0.5} = 63.2$

Base Plate

Effec. Baseplate width = $B = 5.09$ in

Effec. Baseplate Depth = $D = 4.66$ in

width = $a = 3.00$ in

depth = $b = 2.69$ in

midway dist face of column to edge of plate = $c = 4.05$ in

midway dist face of column to edge of plate = $e = 3.68$ in

Column Loads

DEAD LOAD = $D = 75$ lb per column

unfactored ASD load

PRODUCT LOAD = $P = 4,500$ lb per column

unfactored ASD load

$P_{app} = 3,015$ lb per column

P-seismic = $E = (Movt / \text{Frame depth})$

= 441 lb per column

unfactored Limit State load

$B = 0.7000$

$\rho = 1.3000$

$Sds = 0.1056$

$1.2 + 0.2 \cdot Sds = 1.2211$

$0.9 - 0.20 \cdot Sds = 0.8789$

Load Case 1) $(1.2 + 0.2 \cdot Sds)D + (1.2 + 0.2 \cdot Sds) \cdot B \cdot P + \rho \cdot E$ RMI SEC 2.2 EQTN 5

= $1.22112 \cdot 75 \text{ lb} + 1.22112 \cdot 0.7 \cdot 4500 \text{ lb} + 1.3 \cdot 441 \text{ lb}$

= 4,511 lb

Load Case 2) $(0.9 - 0.2 \cdot Sds)D + (0.9 - 0.2 \cdot Sds) \cdot B \cdot P_{app} + \rho \cdot E$ RMI SEC 2.2 EQTN 7

= $0.87888 \cdot 75 \text{ lb} + 0.87888 \cdot 0.7 \cdot 3015 \text{ lb} + 1.3 \cdot 441 \text{ lb}$

= 2,494 lb

Load Case 3) $1.2 \cdot D + 1.4 \cdot P$ RMI SEC 2.2 EQTN 1,2

= $1.2 \cdot 75 \text{ lb} + 1.4 \cdot 4500 \text{ lb}$

= 6,390 lb

Load Case 4) $1.2 \cdot D + 1.0 \cdot P + 1.0 \cdot E$ ACI 318-14 Sec 5.3.1

= 5,031 lb

Eqtn 5.3.1e

Effective Column Load = $P_u = 6,390$ lb per column

Puncture

$A_{punct} = [(c+t) + (e+t)] \cdot 2 \cdot t$

= 236.64 in²

$F_{punct1} = [(4/3 + 8/(3 \cdot \beta))] \cdot \lambda \cdot (F'_c)^{0.5}$

= 143.1 psi

$F_{punct2} = 2.66 \cdot \lambda \cdot (F'_c)^{0.5}$

= 100.9 psi

$F_{punct \text{ eff}} = 100.9$ psi

$f_v / F_v = P_u / (A_{punct} \cdot F_{punct})$

= **0.268 < 1 OK**

Slab Bending

$P_{se} = DL + PL + E = 6,390$ lb

$A_{soil} = (P_{se} \cdot 144) / (f_{soil})$

= 1,227 in²

$x = (L - y) / 2$

= 9.6 in

$F_b = 5 \cdot (\phi) \cdot (f'_c)^{0.5}$

= 189.74 psi

$L = (A_{soil})^{0.5}$

= 35.03 in

$M = w \cdot x^2 / 2$

= $(f_{soil} \cdot x^2) / (144 \cdot 2)$

= 239.3 in-lb

$y = (c \cdot e)^{0.5} + 2 \cdot t$

= 15.9 in

$S_{slab} = 1 \cdot t_{eff}^2 / 6$

= 6.0 in³

$f_b / F_b = M / (S_{slab} \cdot F_b)$

= **0.210 < 1, OK**

Structural Engineering & Design Inc.

1815 Wright Ave., La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.593.8561

Cantilever Rack Analysis

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Design Data

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

- 1) The analysis presented herein conforms to the requirements of the 2021 IBC and ASCE 7-16
- 2) W & S Shape steel conforms to ASTM A572, Gr. 50, with minimum yield, $F_y = 50$ ksi
Formed steel conforms to ASTM A570, Gr. 50, with minimum yield, $F_y = 50$ ksi
Other steel conforms to ASTM A36, Gr. 36, with minimum yield, $F_y = 36$ ksi
- 3) Bolts shall conform to ASTM A325-N unless noted otherwise on the plans or calculations.
- 4) Anchor bolts shall be provided by installer per ICC reference on plans and calculations herein. Installer must provide any special inspection as called out on plans or calculations, or as required by the ICC report indicated herein.
- 5) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.
- 6) 6 in Thk x 4000 psi slab with 750 psf soil bearing pressure

Seismic Design Coefficient

$S_s = 0.0990$
 $S_1 = 0.0680$
 $F_a = 1.6000$
 $F_v = 2.4000$
 $S_{ds} = 0.1057$
 $S_{d1} = 0.1089$

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Summary of Results

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

144 IN H
48 IN ARM AND BASE LENGTH
48 IN BRACE HEIGHT
48 IN COLUMN SPACING

Rack Dimensions & Loads

Arm	Elev	Unif. Arm Load
h1	36 in	2,400 lb
h2	72 in	2,400 lb
h3	108 in	2,400 lb

Seismic Coeff $S_s = 0.099$

Seismic Coeff $F_a = 1.600$


Summary of Components & Results

Column	$F_y = 50$ ksi	W8x18	0.46	OK
Base	$F_y = 50$ ksi	W8x18	0.38	OK
Arm	$F_y = 50$ ksi	S5x10	0.40	OK
Arm Connection		(4) 3/4" Diam Bolts, Grade 5 or better	0.44	OK
Brace	$F_y = 36$ ksi	X Brace: 1.575x0.984x105 Strut L2x2x3/16	0.02	OK
X Brace Connection	Bolted	(1) 0.5 in diam Bolt per end	0.03	OK
Anchors	ESR 4266	0.75 in diam x 4.75 in embed HILTI TZ2 with inspection 4 per base	0.09	OK
Slab & Soil		6 in thick x 4000 psi with 750 psf soil at grade	0.22	OK

Notes

ALL LOADS SHOWN ARE PER ARM, UNIFORM LOAD, NO TIP LOADS, NO DROPPED LOADS, NO IMPACT LOADS

OMEGA = 2.0



Structural

Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Seismic Loads

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

Seismic Eqtn:	Transverse	Longitudinal
Cs1=	Sds*I/R	
=	0.042	0.033
Cs2=	0.044*Sds*I	
=	0.005	0.005
Cs3=	0.5*S1*I/R	
=	0.014	0.010

Rtrans= 2.5

Ss= 0.099

Rlong= 3.25

S1= 0.068

Sides=n= 1

Fa= 1.600

Arms= 3

Fv= 2.400


Sds= 0.106

Sd1= 0.109

I= 1.0

phi= 0.67

** DL per arm= 127.0 lb



Side Elevation

** weight of arm plus trib weight of column per level

Vtrans= 0.0423

Vlong= 0.0325

Σ Arm LL= 7,200 lb

Σ Arm LL*phi= 4,824 lb

Σ Arm DL= 381 lb

W1=W_{arm,gravity}= 7,581 lb

W2=W_{arm,seismic}= 5,205 lb

V-transv= 0.0423 * 5205 lb

= 220 lb/frame

trans shear per upright

V-long= 0.0325 * 5205 lb

= 169 lb/frame

longit shear per upright

Lateral Force Distribution

Level	Transverse Force						Longitudinal Force
	W1 (DL+LL)*n	W2 (DL+LL*phi)	hx	wxhx	Fi	Fi * hi	Fi
1	2,527 lb	1,735 lb	36 in	62460	37 lb	1,332 in-lb	28 lb
2	2,527 lb	1,735 lb	72 in	124920	73 lb	5,279 in-lb	56 lb
3	2,527 lb	1,735 lb	108 in	187380	110 lb	11,880 in-lb	85 lb

Σ= 374,760 220 lb 18,491 in-lb

Summary of Frame Loads

Mseismic= 18,491 in-lb

Mwind= 24,019 in-lb

Pcol= 7,581 lb DL+LL

Marm-max= (LL-max+DL) * (Arm Length/2)

= (2400 lb + 31 lb) * (48 in/2)

= 58,344 in-lb

Marm-total= Σ Marm

= 175,032 in-lb

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply



Project #: 25-0625-3

Arm

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

Analysis is based on a uniformly loaded arm with no tip or impact loads considered.

Arm Type= S5x10
 $I_x = 12.3000 \text{ in}^4$
 $S_x = 4.920 \text{ in}^3$
 $F_y = 50,000 \text{ psi}$
 $L = 48 \text{ in}$



Check Arm Bending

$LL_{\text{-max}} = 2,400 \text{ lb}$

$DL = 31 \text{ lb}$

$M = W * L/2$
 $= 58,344 \text{ in-lb}$

$f_b = M/S_y$
 $= 11,859 \text{ psi}$

$F_b = 0.6 * F_y$
 $30,000 \text{ psi}$

$f_b/F_b = 0.40 \quad \text{OK}$

Check Arm Deflection

$E = 29,000,000 \text{ psi}$

$D = w * L^4 / (8 * E * I_x)$
 $= 0.0973 \text{ in}$

$D_{\text{allow}} = L/180$
 $= 0.27 \text{ in} \quad \text{OK}$

Check Bolts For Imposed Arm Loads

Spacing= $d = 4.0 \text{ in}$

Bolt diameter= 0.75 in

$F_t = 44,000 \text{ psi}$

$F_v = 21,000 \text{ psi}$

$t_{\text{min}} = 0.188 \text{ in}$

$F_u = 58,000 \text{ psi}$

Bolts in shear= $N_s = 4$

Bolts in tension= $N_t = 2$


$M = 58,344 \text{ in-lb}$

$T = M/d$
 $= 14,586 \text{ lb}$

$W = LL + DL$
 $= 2,431 \text{ lb}$

$W/\text{Bolt} = 608 \text{ lb}$

$T/\text{Bolt} = 7,293 \text{ lb}$



Arm to Column Connection

Shear Capacity= Bolt Area * F_v
 $= [(0.75 \text{ in})^2 * \pi/4] * 21000 \text{ psi}$
 $= 9,278 \text{ lb}$

Bearing Capacity= Bolt Diam * $t_{\text{min}} * F_u * 1.2$
 $= 9,788 \text{ lb}$

Tension Capacity= Bolt Area * F_t
 $= 19,439 \text{ lb}$

Combined stresses: $(608 \text{ lb}/9278 \text{ lb}) + (7293 \text{ lb}/19439 \text{ lb}) = 0.44 \quad \text{OK}$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Column Load Case: DL+LL

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

Section

Section= W8x18

Area= 5.26 in²

Ix= 61.90 in⁴

Sx= 15.20 in³

rx= 3.43 in

Iy= 7.97 in⁴

Sy= 3.04 in³

ry= 1.23 in

Fy= 50,000 psi


Kx= 2.4

Ky= 1.0

Lx= 108 in

Ly= 48 in

Cm= 1.00



Loads (Single Face Rack-Full Static Arm Loads)

Check Load Case 2 ASCE 2.4.1: ; DL + LL <= 1.0, ASD Method

Pmax= 7,581 lb

Mstatic= 175,032 in-lb

COLUMN DL= 381 lb

COLUMN PL= 7,200 lb

Mstatic= 175,032 in-lb

Combined Stress

$$(kl/r)_x = (2.4 \times 108 \text{ in} / 3.43 \text{ in}) \\ = 75.57$$

$$(kl/r)_y = (1 \times 48 \text{ in} / 1.23 \text{ in}) \\ = 39.02$$

$$(kl/r)_{\max} = 75.57$$

$$C_c = (2\pi^2 E / F_y)^{0.5} \\ = 107.0$$

SINCE $(KL/r)_{\max} < C_c$, USE EQTN E2-1

$$F_a = \frac{[1 - ((kl/r)^2 / 2C_c^2)] F_y}{5/3 + 3(kl/r) / 8C_c - (kl/r)^3 / 8C_c^3} \\ = 19,884 \text{ psi}$$

$$f_a = P / \text{AREA} \\ = 1,441 \text{ psi} \\ f_a / F_a = 0.07 < 0.15$$

$$f_{bx} = M / S \\ = 11,515 \text{ psi}$$

$$F_{bx} = 0.6 F_y \\ = 30,000 \text{ psi}$$

$$F'_{ex} = (12 \pi^2 E) / (23 (KL/r)^2) \\ = 26,150 \text{ psi}$$

$$f_b / F_b = 0.38$$

$$(1 - f_a / F_e) > 0 = 1.00$$

(H1-3):

$$f_a / F_a + f_b / F_b = 0.46 \leq 1 \text{ OK}$$

Check Base Bending

Section= W8x18

Sx= 15.20 in³

Fy= 50,000 psi

Fbx= 0.6 Fy

= 30,000 psi

Mbase-static= 175,032 in-lb

$$f_b / F_b = 0.38$$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Column Load Case: DL+LL+ Lateral Load **Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK**

Section

Section= W8x18

Area= 5.26 in²

Ix= 61.90 in⁴

Sx= 15.20 in³

rx= 3.43 in

Iy= 7.97 in⁴

Sy= 3.04 in³

ry= 1.23 in

Stress Increase= 1.00

Fy= 50,000 psi


Kx= 2.4

Ky= 1.0

Lx= 108 in

Ly= 48 in

Cm= 1.00



Loads (Single Face Rack-Full Arm Loads plus lateral loads)

Check Load Case 6b ASCE 12.4.2.3: $(1+0.10*Sds)D + 0.75L + 0.525E \leq 1.0$, ASD Method

Pmax= 1.01 * 381 lb + 0.75 * 7200 lb

= 5,785 lb

M= 0.75*175032 in-lb + 18491 in-lb * 0.525

= 140,982 in-lb

(Mstatic + Mwind)

COLUMN DL= 381 lb

COLUMN PL= 7,200 lb

Mstatic= 175,032 in-lb

Mseismic= 18,491 in-lb

Sds= 0.1057

1+0.10*Sds= 1.0100

Combined Stress

$(kl/r)_x = (2.4*108 \text{ in}/3.43 \text{ in})$

= 75.57

$C_c = (2\pi^2 E/F_y)^{0.5}$

= 107.0

$(kl/r)_y = (1*48 \text{ in}/1.23 \text{ in})$

= 39.02

$(kl/r)_{\text{max}} = 75.57$

SINCE $(KL/r)_{\text{max}} < C_c$, USE EQTN E2-1

$F_a = \frac{[1 - ((kl/r)^2 / 2C_c^2)] F_y}{5/3 + 3(kl/r)/8C_c - (kl/r)^3 / 8C_c^3}$

= 19,884 psi

$f_a = P/AREA$

= 1,100 psi

$f_a/F_a = 0.06 < 0.15$

$f_{bx} = M/S$

= 9,275 psi

$F_{bx} = 0.6 * F_y$

= 30,000 psi

$F'_{ex} = (12 * \pi^2 * E) / (23 * (KL/r)^2)$

= 26,150 psi

$f_b/F_b = 0.31$

$(1 - f_a/F_e) = 1.00$

(H1-3):

$f_a/F_a + f_b/F_b = 0.36 \leq 1$ OK

Check Base Bending

Section= W8x18

Sx= 15.20 in³

Fy= 50,000 psi

$F_{bx} = 0.6 * F_y$

= 30,000 psi

Mbase-lateral= 140,982 in-lb

$f_b/F_b = 0.31$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Anchors

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK

Check Load Case 7 ASCE 12.4.2.3: : $(0.9-0.20*Sds)DL + (0.9-0.20*Sds)Papp + E$

Overtuning Forces

Seismic Forces

Seismic Ovt Moment=Mseismic= 18,491 in-lb

Rack DL= 381 lb *load per upright*
 LL_{eff}=Total LL*0.67=P_{app}= 4,824 lb *load per upright*


M_{stabilizing}=M_{st}= $[0.879*(381 \text{ lb}+4824 \text{ lb})]*56.14 \text{ in}/2$
 = 128,426 in-lb

T-seismic= $[M_{\text{seismic}} - M_{\text{st}}]/d * \Omega$
 = 0 lb
net seismic uplift

Seismic shear= 220 lb/frame

Seismic Tension per anchor= 0 lb

Seismic Shear per anchor= 55 lb



Side Elevation

Base depth= 48.0 in
 Column depth= 8.1 in
 d= 56.1 in
 $0.9-0.20*Sds= 0.879$

Check Anchors

Anchor Type= 0.75 in diam x 4.75 embed HILTI TZ2 Per ICBO ESR 4266

Anchor Inspection Required? Yes

Anchor/base= 4

Tallow= 1,961 lb

Stress Increase= 1

Anchor/end= 2

Vallow= 2,517 lb

Eqtn Exponent= 1

	Tension/anchr	Shear/anchr	Tallow	Vallow	Interactn Eq.	Status
Seismic	0 lb	55 lb	1,961 lb	2,517 lb	0.022	OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Bob S

Project: Butler Supply

Project #: 25-0625-3

Base to Column Connection

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK



$h1 = 6.0$ in

$h2 = 4.0$ in

$h3 = 2.0$ in

$M_D = 2,232$ in-lb

$M_P = 172,800$ in-lb

$M_E = 18,491$ in-lb

$\beta = 0.7$

$p = 1.3$

$Sds = 0.106$

$\Omega = 2$

Bolt Diam = 0.750 in

$F_t = 19.40$ kip (Grade 5 or better)

Base to Column Elevation

$$T1 = F_t \times 2 \\ = 38.80 \text{ kip}$$

$$T2 = T1 \times h2/h1 \\ = 25.87 \text{ kip}$$

$$T3 = T1 \times h3/h1 \\ = 12.93 \text{ kip}$$

$$\text{Moment Capacity} = M_{cap} = T1 \times h1 + T2 \times h2 + T3 \times h3 + T4 \times h4 + T5 \times h5 + T6 \times h6 \\ = 362 \text{ in-kip}$$

Load Case 1 (ANSI MH16.3-2016 Sec 2.1)

$$D+P = 175,032 \text{ in-lb}$$

$$\text{Load Case 5} \quad (1+0.105 \times Sds) \times D + 0.75 \times [1.4 + 0.14 \times Sds] \times \beta \times P + L + S + 0.7 \times p \times E = 143,227 \text{ in-lb}$$

$$\text{Load Case 6} \quad (1+0.14 \times Sds) \times D + (0.85 + 0.14 \times Sds) \times \beta \times P + 0.7 \times p \times E = 123,697 \text{ in-lb}$$

$$\text{Load Case 7} \quad (0.6 - 0.14 \times Sds) \times D + (0.6 - 0.14 \times Sds) \times P_{app} + 0.7 \times E \times \Omega = -51,167 \text{ in-lb}$$

Check Longitudinal Brace

$$M_{demand} = 175.0 \text{ in-kip}$$

OK

Brace Type = X Brace

Brace = 1.575x0.984x105

Area = $A_n = 0.337$ in²


$V_{long} = 169$ lb

$$T = 0.525 \times V_{long} \times L_{diag}/L_h \\ = 126 \text{ lb}$$

$$F_t = 0.6 \times F_y \\ = 21,600 \text{ psi}$$

$$f_t = T/A_n \\ = 374 \text{ psi}$$

$$f_t/F_t = 0.02 < 1.0, \text{ OK}$$



Brace Panel Elevation

Bay Width = $L_h = 48.0$ in

Brace Panel Ht = $L_v = 48.0$ in

$L_{diag} = 68.0$ in

$F_y = 36,000$ psi

Check Brace Connection

Connection = Bolted

$F_v\text{-bolt} = 21,000$ psi

Bolts = 1

Bolt Diam = 0.5

Bolt Capacity = Bolt Area * $F_v\text{-bolt}$

$$= 4,123 \text{ lb}$$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S


Project: Butler Supply

Project #: 25-0625-3

Footing


Load case: DL+ LL

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK



Thickness= $t= 6.0$ in
 $f'_c= 4,000$ psi
 $f_{\text{soil}}= 750$ psf
 base depth= $d= 56.14$ in

Base width= $W= 5.25$ in
 $B= 3$
 Stress Increase= $a= 1.00$
 $\phi= 0.65$
 $c= 17.3$ in



Check Puncture

$$P_{\text{gravity}} = 7,581 \text{ lb}$$

$$M_{\text{base}} = 175,032 \text{ in-lb}$$

$$P_{\text{ovt}} = M_{\text{base}} / (d * 0.66) \\ = 4,724 \text{ lb}$$

$$P = 1.4 * (P_{\text{gravity}} + P_{\text{ovt}}) \\ = 17,227 \text{ lb}$$

$$F_p = [(4/3) + (8/3)/B] * (f'_c)^{0.5} < 2.66 * (f'_c)^{0.5} * a \\ = 140.5 \text{ psi}$$

$$\text{Punct Area} = A = (d + t) + (W + t) * 2 * t \\ = 880.7 \text{ in}^2$$

$$\text{Puncture Stress} = (P/A) / F_p \\ = 0.14$$

OK

Check Bending

$$A_{\text{req}} = P / f_{\text{soil}} \\ = 3308 \text{ in}^2 \\ = 191.7 \text{ in} \quad \times \quad 17.3 \text{ in}$$

$$b = 191.7 \text{ in} - (56.14 \text{ in} + 2 * 6 \text{ in}) \geq 0 \\ = 123.56 \text{ in}$$

$$M_{\text{slab}} = f_{\text{soil}} * c * b^2 / (2 * 144) \\ = 4,763 \text{ in-lb}$$

$$S = c * t^2 / 6 \\ = 103.5 \text{ in}^3$$

$$F_b = 5 * \phi * (f'_c)^{0.5} * a \\ = 205.5 \text{ psi}$$

$$f_b / F_b = (M_{\text{slab}} / S) / F_b \\ = 0.22$$

OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Bob S


Project: Butler Supply

Project #: 25-0625-3

Footing


Load case: DL+ LL + Lateral

Configuration: TYPE 2 SGL-SIDED CANTILEVER RACK



Thickness= $t= 6.0$ in
 $f'_c= 4,000$ psi
 $f_{\text{soil}}= 750$ psf
 base depth= $d= 56.14$ in

Base width= $W= 5.25$ in
 $B= 3$
 Stress Increase= $a= 1.00$
 $\phi= 0.65$
 $c= 17.3$ in



Check Puncture

$$P_{\text{gravity}}= 5,785 \text{ lb}$$

$$M_{\text{base}}= 140,982 \text{ in-lb}$$

$$P_{\text{ovt}}= M_{\text{base}}/(d \cdot 0.66) \\ = 3,805 \text{ lb}$$

$$P= 1.2 \cdot P_{\text{gravity}} + P_{\text{ovt}} \\ = 10,351 \text{ lb}$$

$$F_p= [(4/3) + (8/3)/B] \cdot (f'_c)^{0.5} < 2.66 \cdot (f'_c)^{0.5} \cdot a \\ = 140.5 \text{ psi}$$

$$\text{Punct Area}=A= (d + t) + (W + t) \cdot 2 \cdot t \\ = 880.7 \text{ in}^2$$

$$\text{Puncture Stress}= (P/A)/F_p \\ = 0.08$$

OK

Check Bending

$$A_{\text{req}}= P/f_{\text{soil}} \\ = 1987 \text{ in}^2 \\ = 115.2 \text{ in} \quad \times \quad 17.3 \text{ in}$$

$$b= 115.2 \text{ in} - (56.14 \text{ in} + 2 \cdot 6 \text{ in}) \geq 0 \\ = 47.06 \text{ in}$$

$$M_{\text{slab}}= f_{\text{soil}} \cdot c \cdot b^2/(2 \cdot 144) \\ = 691 \text{ in-lb}$$

$$S= c \cdot t^2/6 \\ = 103.5 \text{ in}^3$$

$$F_b= 5 \cdot \phi \cdot (f'_c)^{0.5} \cdot a \\ = 205.5 \text{ psi}$$

$$f_b/F_b= (M_{\text{slab}}/S)/F_b \\ = 0.03$$

OK