

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251620
Address: 2717 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, July 08, 2025

Corrective Action Required:

1	Misc	PORTAL FRAME ONLY
		- portal frame sheeting nail pattern ok
		- back patio door CSPF, sheeting break to be in middle 1/3 of leg. make lower portion at least 4 foot for a 12 foot hieght header. block and nail off. (I will check at All rough)
		- back deck ceiling, ok
		- front porch ceiling, ok

Comments: