

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Mitchell Schwarz	Failed	Tuesday, July 08, 2025

Corrective Action Required:

1	Misc	Pre final units only segment H 4th floor 2421-smoke detector not permitted within 6' of range, secure electrical at island, afci protection required at laundry 2420-secure mc at island 2419-afci at laundry 2414- GFCi within 6' of sink required 2413-secure mc at island 3rd floor 2321 -hot neutral reverse at patio outlet -master bath fan "pulsing" -secure dishwasher line under kitchen sink -secure electrical under kitchen sink 2319 -master bath fan "pulsing" 2318 -bedroom sprinkler accustom plate needs to be installed around sprinkler
---	------	--

Comments: