

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Detention Basin	Dustin Agcopra	Failed	Wednesday, July 09, 2025

Informational:
1 Misc 4-16-24 BR Contractor installed detention basin structure and 50' of 30" RCP.
7-9-25 Dustin A, Basin is silting in all around the pond due to no fabric behind rock retaining wall.

Comments: