

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246440
Address: 2769 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Thursday, July 10, 2025

Corrective Action Required:

1	Misc	- Pay all fees - final grading and sod - Sump discharge to be 36" away from foundation - Provide splash pads at down spouts - Seal exterior penetration at gas piping - Driveway and sidewalk inspections pending
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	- EXTENDED Shawn Hoffman 07/10/2025 9:30 AM
---	--------------------------	---

Comments: