

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Thursday, July 10, 2025

Corrective Action Required:

1	Misc	Pre final units only segment H 4th floor Units ok 3rd floor -Doors to be self closing and latching 2nd floor -Doors to be self closing and latching 2214-Gfci required within 6' of sink 2217-Gfci required within 6' of sink 2218-Gfci required within 6' of sink, secure dishwasher dishcharge line above sink 2219-Gfci required within 6' of sink 2220-Secure mc at island, Gfci required within 6' of sink 2221-Missing cover at dryer vent
---	------	--

Comments: