

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251301
Address: 2766 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, July 11, 2025

Corrective Action Required:

1 Misc Fb= Fire block

- Fb top of HVAC chase in pantry (behind ductwork)
- Complete anchor at stairs landing corner
- Missing anchor bolts of sill plates in garage 3 locations
- Nail off exterior sheeting at single bay to code

Comments: