

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

### Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Robb Popp	Partial	Monday, July 14, 2025

Corrective Action Required:

1	Misc	Pre final units only segment H 4th floor Units ok  3rd floor -Doors to be self closing and latching  2nd floor -OK  1st floor 2416-Breaker 16 faulty 2422-Secure dishwasher discharge line, missing dryer vent cover **Garages not inspected
---	------	---

**Comments:**