

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250722
Address: 2108 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Monday, July 14, 2025

Corrective Action Required:

1	Misc	-PFH at garage open is good -Front and back porch ceilings are ok to -cover - cs-pf on dining room back wall and owners suite back wall need appropriate sized straps on inside and as per code 3" grid pattern nailing at headers
---	------	--

Corrective Action Required:

2	Misc	2108 SW Wheatfield dr - Attic access needed for garage / kitchen space - Missing nails in joists hanger on lvl in kitchen - Secure wire within 12" at back of fireplace - Plans call for 3 continuous 2x6 between windows on back living room wall - Basement column at end of wall bottom of stairs to be 3 1/2" id, 4" od
---	------	--

Comments: