

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242901
Address: 60 SE THOMPSON DR, Unit:A, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Monday, July 14, 2025

Informational:
1 Misc 7-11-25 Dustin A, Sw is formed and compacted. Approved to pour.
7-14-25 Dustin A, Sw was reinspected due to rain. ADA ramp had to be dug out . Ada ramp was fixed approved to pour.

Comments: