

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20240980

Address: 1375 SE HAMBLER RD, LEES SUMMIT, MO 640811440 SE BROADWAY DR, LEES SUMMIT, MO
640811450 SE BROADWAY DR, LEES SUMMIT, MO 640811460 SE BROADWAY DR, LEES
SUMMIT, MO 640811270 SE BROADWAY CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface		Partial	Monday, July 14, 2025

Informational:

1	Misc	12-10-24 BR Contractor laid 6" KCMMA A3 base on 100% SE Hamblen Rd with 93% - 96% compaction by 3rd party tester(Geotech). 7-14-25 Dustin A, Shoulder has been poured as per plans.
---	------	--

Comments: