



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113727, Building Permit - Commercial  
Address: 2741 NE MCBAIN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Friday, February 24, 2012

Corrective Action Required  
1 MISC

OK TO DROP TILES AT FOLLOWING SPACES:

-1ST FLOOR EXCEPT AT CORRIDOR AND NURSING STATION  
-2ND FL OK EXCEPT AT LOCATION OF RETURN AIR NOT  
INSTALLED

**Comments:**