SITE PLAN NOTES:

REQUIREMENTS.

SEE PLUMBING PLANS.

(8) EV CHARGING PEDESTAL.

—w — DOMESTIC WATER —F — FIRE SERVICE

☐ PROPOSED TRANSFORMER UG PRIMARY/SECONDARY SANITARY SEWER

—T— TELECOMMUNICATION SERVICE

9 2 HOUR TIMER.

10 EPO FIRE PIT.

SEE CIVIL, ARCHITECTURAL, AND LANDSCAPE DRAWING FOR

REGARDS TO INTERFACING WITH THEIR WORK AND INCLUDE

TRANSFORMER AND PRIMARY LOCATIONS ARE AS PREFERRED

AND NEED VERIFICATION WITH THE PROVIDER AS TO FINAL LOCATIONS BASED ON THEIR DESIGN AND CONTRACTOR

ALL SITE LIGHTING CIRCUITS ROUTE THROUGH PHOTOCELL AND HAVE (3) #10 WIRES UNLESS NOTED OTHERWISE.

NOTIFY UTILITY PROVIDERS PRIOR TO ANY EXCAVATION, TRENCHING, OR GRADING TO MARK UTILITIES.

PROVIDE ALL UTILITY PROVIDER REQUIREMENTS WITH

ALL ITEMS REQUIRED FOR PROPER INSTALLATION.

FURTHER INFORMATION AND WORK.

1) DOMESTIC AND FIRE CONNECTION POINT.

(2) SANITARY CONNECTION POINT. SEE PLUMBING PLANS.

(4) 24"Wx36"Lx30"D QUAZITE HANDHOLE FOR VOICE/DATA

 $\langle 5 \rangle$  (3) 4"C. WITH PULL STRINGS FOR VOICE/DATA PROVIDER

(6) GARAGE PANEL FED FROM BUILDING HOUSE PANEL.

(7) GARAGE CIRCUITS FED FROM ADJACENT GARAGE PANEL.

SYMBOLS LEGEND

WITH UTILITY PROVIDER(S) AND CIVIL PLANS

CABLING AT 36" MINIMUM BELOW GRADE

3 4" ROOF DRAIN CONNECTION POINT. SEE PLUMBING PLANS.

PROVIDER CABLING. VERIFY SIZE, QUANTITY AND LOCATION





MITSCH

DESIGN

200 S. Rangeline Rd. | Suite 226

Carmel, Indiana 46032

317.573.2222 www.mitschdesign.com

3639 SW Summerfield Drive, Suite A Topeka, Kansas 66614-3974

Telephone: (785) 233-3232

FAX: (785) 233-0647 Email: lsapa@lsapa.com

LSA PROJECT NO. 2404033







