



- NOTES:
1. ALL DRAIN, WASTE AND VENT PIPING IS 2" UNLESS NOTE OTHERWISE.
  2. ALL SUPPLY PIPING IS 1/2" UNLESS NOTED OTHERWISE. SUPPLY PIPING IS BELOW SLAB AS SHOWN.
  3. CONNECT ALL APPLIANCES OR EQUIPMENT PER MANUFACTURER'S INSTRUCTIONS.
  4. ALL PLUMBING VENTS SHALL BE 10 FEET FROM OPENINGS OR INTAKES.
  5. THERE SHALL BE NO PVC WITHIN RETURN AIR PLENUMS.
  6. ALL FIXTURES SHALL HAVE BLADDER TYPE SHOCK SUPPRESSORS FOR EACH CHASE.
  7. SEE THE ARCHITECTURAL DRAWINGS FOR ALL FIXTURES MOUNTING HEIGHTS.
  8. REFER TO THE ARCHITECTURAL DRAWINGS FOR FLOOR DRAIN LOCATIONS AND FLOOR SLOPES IF PRESENT. FLOOR DRAINS ARE TYPE 1, 2" UNLESS NOTED OTHERWISE.
  9. ROUTE DRAIN PIPING FROM WATER HEATERS, AIR HANDLERS OR EQUIPMENT TO FLOOR DRAINS. PROVIDE PROPER TRAPS.
  10. ROUTE NO PIPING OVER ELECTRICAL EQUIPMENT.
  11. PROVIDE 1/2" TYPE 1-PC INSULATION ON HW PIPING FOR 8FT AFTER WATER HEATER.
  12. SEE ARCHITECTURAL DRAWINGS FOR FIXTURES AND DETAILS.

EVREN APARTMENTS  
NEW CONSTRUCTION  
EVREN APARTMENTS CLUBHOUSE  
LEE'S SUMMIT, MISSOURI  
PERMIT SET



MD PROJECT #:	24097		
DRAWN BY:	CAD		
CHECKED BY:	RRB		
PRELIMINARY PRICING SET PERMIT SET	-		
	5/31/2024		
REVISION SCHEDULE			
#	DATE	DESCRIPTION	
1	07/08/24	TRACKER REVISION	
2	01/23/25	CITY COMMENTS 2	
3	04/16/25	COORDINATION	

ALL IDEAS, DESIGNS AND PLANS (ORIGINAL WORKS OF AUTHORSHIP FIXED IN A TANGIBLE MEDIUM OF EXPRESSION) INDICATED OR PRESENTED BY THESE DRAWINGS AND DOCUMENTS ARE OWNED BY, AND ARE THE PROPERTY OF, MITSCH DESIGN. ALL RIGHTS RESERVED. EXCEPT FOR USES EXPRESSLY PERMITTED IN WRITING.

PARTIAL  
CLUBHOUSE PLAN -  
PLUMBING

P102