

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250888
Address: 2622 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Tuesday, July 15, 2025

Informational:	
1 Misc	Portal frame at garage ok to cover
Corrective Action Required:	
2 Misc	Fire blocking needed above kick out in living room

Comments: