



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20245783	Date:	July 15, 2025
Project Title:	LEE'S SUMMIT JOINT OPERATIONS FACILITY	Applicant:	
Location:	2 NE TUDOR RD, LEES SUMMIT, MO 64086	Titan Built, LLC	
Type of Work:		8207 Melrose Drive, #200	
Occupancy Group:	B	Lenexa, KS 66214	
Description:	LEE'S SUMMIT JOINT OPERATIONS FACILITY - NEW FIRE DISPATCH, ADMIN, FIRE TRAINING, AND EMERGENCY OPERATIONS CENTER	Primary: (913) 953-8650	
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Action Required: Make alerting devices in rooms 005, 004, 121, 120, 116, 115, 107, 105, 138, and 140 strobes only.
2. Action Required: Add strobs to rooms 036 and 038.
3. Action Required: Envision Technology Group need a city business license before plans will be approved. Please forward this letter to Envision.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.