

DEVELOPMENT SERVICES

Residential Plan Review

July 15, 2025

CLAYTON PROPERTIES GROUP, INC 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

Permit No: PRRES20252932

Plan Name:

Project Address: 1206 SE WINDBREAK DR, LEES SUMMIT, MO 640811204 SE WINDBREAK DR, LEES SUMMIT, MO 64081

Parcel Number: 337478

Location: CORNERSTONE AT BAILEY FARMS FIRST PLAT LOTS 1 THRU 37 AND TRACT A --- LOT 32

Type of Work: NEW DUPLEX

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW DUPLEX. UNFINISHED BASEMENT. ROOF TRUSSES.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Andrea Sessler Rejected

1. Contours, spot elevations and drainage flow arrows (as required) shall be provided on the lot.

DRAINAGE ARROW ON EAST SIDE SHOWS IT'S ON THE ADJACENT PROPERTY. PLEASE PUT THE ARROW ON THIS LOT IF DRAINAGE ALLOWS AS THERE ARE MULTIPLE WINDOW WELLS THERE AND IT CANNOT BE INDICATED THAT THE DRAINAGE WILL BE OCCURING ON THE ADJACENT PROPERTY DUE TO THAT.

Residential Plan Review Reviewed By: Andrea Sessler Approved

Planning Review RES Reviewed By: Ian Trefren Approved

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	

Residential, Finished basements Residential, garage Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		26		
		934 3268		
Roofing Material		Number of Bathrooms	4	
Number of Bedrooms	6	Number of Stories	1	
Number of Living Units	2	Total Living Area	3284	