

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245644

Address: 1403 SW WINTHROP TER, LEES SUMMIT, MO 64081
1401 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Jamie Simerly	Passed	Wednesday, July 16, 2025

Informational:

1 Misc

06/24/25 Jamie S, DW is formed and compacted. Approved to Pour.
07/01/25 Jamie S, Curb on driveway needs to be grouted. Call in for reinspection once it has been completed.
07/16/25 Jamie S, DW is in compliance with city standards.

Comments: