

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20235113

Address: 2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 64064 2740 NE HAGAN RD, Unit:B, LEES SUMMIT,  
MO 64064 2740 NE HAGAN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Thursday, July 17, 2025

Corrective Action Required:

1	Misc	Restrooms, laundry, and bathroom not ready for inspection. Screw dryer duct joints (no more than 1/8" into duct) and seal all duct joints. Complete exhaust fan installation for bathroom
---	------	---

Corrective Action Required:

2	Misc	OK to cover: -Vestibule 110
---	------	--------------------------------

**Comments:**