



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20245783	Date:	July 15, 2025
Project Title:	LEE'S SUMMIT JOINT OPERATIONS FACILITY	Applicant:	
Location:	2 NE TUDOR RD, LEES SUMMIT, MO 64086		Titan Built, LLC 8207 Melrose Drive, #200 Lenexa, KS 66214
Type of Work:			
Occupancy Group:	B		
Description:	LEE'S SUMMIT JOINT OPERATIONS FACILITY - NEW FIRE DISPATCH, ADMIN, FIRE TRAINING, AND EMERGENCY OPERATIONS CENTER		Keith Williams - Titan Built <NO STREET ADDRESS>
Construction Type:	Type IIB (Unprotected)		
Map Page:		Primary:	(913) 439-8638

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Action Required: Make alerting devices in rooms 005, 004, 121, 120, 116, 115, 107, 105, 138, and 140 strobes only.
2. Action Required: Add strobs to rooms 036 and 038.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.