



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120156, Building Permit - Commercial
Address: 1196 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Tuesday, February 28, 2012

Corrective Action Required

1 MISC

NEC: COMPLETE ELECTRICAL PANEL SCHEDULE; PRINT LEGIBLE AND AFFIX TO INSIDE OF PANEL DOOR

Corrective Action Required

2 MISC

IPC: VENTING REQUIRED AT TWO-COMPARTMENT SINK @ CENTER OF KITCHEN

Corrective Action Required

3 MISC

IPC: VENTING OF THREE-COMPARTMENT SINK @ KITCHEN NORTH MUST EXTEND TO ATMOSPHERE

Corrective Action Required

4 MISC

IPC: DRAIN AT SINK IN SERVING AREA: 1) NO TRAP 2) INDIRECT DRAIN NOT APPROVED

Corrective Action Required

5 MISC

IPC 608: BACKFLOW PREVENTION DEVICE REQUIRED AT ICE MAKER WATER FEED LINE

Occupancy Inspection - Fire	Joe Dir	Passed	Tuesday, February 28, 2012
--	---------	--------	----------------------------

Comments: