

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251603
Address: 2090 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, July 21, 2025

Corrective Action Required:

1	Misc	Inspection for PFH, front porch and back deck roof only
		*PFH-seal penetrations in moisture barrier
		*Front porch-install 2x6 ceiling joists per plan
		*Back deck ceiling-ok to cover

Comments: