

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20246285
Address: 1333 SW WINTHROP TER, LEES SUMMIT, MO 640811331 SW WINTHROP TER,
LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Monday, July 21, 2025

Corrective Action Required

1	Misc	Maintain overgrown vegetation
---	------	-------------------------------

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	7-17-25 Dustin A, Silt fence is down, Storm inlet needs cleaned and curb lone needs cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 7-21-25 Dustin A, Storm inlet still needs to be cleaned.
---	----------------------------	---

Comments: