

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251204
Address: 1309 SW JEFFERSON ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Monday, July 21, 2025

Corrective Action Required:

1 Misc

- drinking fountain not to be above 34"
- bathroom mirrors to be 40" to reflective surface
- toilets to be 16"-18" to center off side wall
- open grounds on gfcis at coffee bar
- open junction box at SW most office
- Address any other outstanding items from other departments

Comments: