



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115556, Building Permit - Commercial
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, February 29, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY 5/8" TYPE X GWB @ REMOVED
AREAS OF CEILING AT NAVE 106 SE/S/SW/W: 1ST OF TWO
LAYERS;

Comments: