CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246059

Address: 440 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Robb Popp Failed Monday, July 21, 2025

Commercial

Corrective Action Required:

1 Misc -Provide accessible restroom signage at latch side of doors

-Restroom mirrors to be max 40" aff

-Sidewall grab bars to be spaced max 12" from back wall -Backwall grab bars to be spaced max 6" from side wall

-Toilets to be 16"-18" from side wall

Comments: