

John Knox Village Meadows North With Fire Flow At Maximum Day Demand

		ID	Base Demand (gpm)	Base Pressure (psi)	Fire Demand (gpm)	Combined Demand (gpm)	Residual Pressure (psi)
1	<input type="checkbox"/>	6500	0.00	99.48	1,000.00	1,000.00	75.76
2	<input type="checkbox"/>	6527	0.00	100.94	1,000.00	1,000.00	81.40
3	<input type="checkbox"/>	6528	0.00	100.00	1,000.00	1,000.00	73.81
4	<input type="checkbox"/>	6529	0.00	97.25	1,000.00	1,000.00	75.26
5	<input type="checkbox"/>	6501	84.01	102.10	0.00	84.01	79.52

John Knox Village With No Fire Flow At Peak Hour Demand

	ID	Base Demand (gpm)	Base Pressure (psi)	Fire Demand (gpm)	Combined Demand (gpm)	Residual Pressure (psi)
1	<input type="checkbox"/> 6500	0.00	78.76	0.00	0.00	78.76
2	<input type="checkbox"/> 6527	0.00	80.58	0.00	0.00	80.58
3	<input type="checkbox"/> 6528	0.00	79.48	0.00	0.00	79.25
4	<input type="checkbox"/> 6529	0.00	76.25	0.00	0.00	76.25
5	<input type="checkbox"/> 6501	168.02	81.45	0.00	168.02	81.45

