



City of Lee's Summit

220 SE Green Street Lee's Summit, Missouri 64063
(816) 969-1600 Fax (816) 969-1619

Commercial Final Development Plan Review

Date: Wednesday, September 26, 2012

To:

Applicant: DEGASPERI &
ASSOCIATES ARCHITECTURE

Email: jeff@daikc.com

Fax #: (913) 647-5301

Engineer: WALLACE
ENGINEERING

Email: mamer@wallacesc.com

Fax #: (816) 421-8338

Property Owner: TOP STAR
LLC

Email:

Fax #: <NO FAX NUMBER>

From: Hector Soto, Planner

Re:

Application Number: PL2012086

Application Type: Commercial Final Development Plan

Application Name: REECE & NICHOLS BUILDING

Location: 5030 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Permitting and Plan Review Division of the Codes Administration Department at 816-969-1200.

Review Status:

Approved: See below and attached for any conditions of approval.

Required Corrections:

Engineering Review	Gene Williams	Senior Staff Engineer	Condition(s) of Approval
	(816) 969-1812	Gene.Williams@cityofls.net	

1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Public Works Review and Inspection Fee of \$3,114.85 (which is based on 3% of the total infrastructure cost plus a water test inspection fee) must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit from the Codes Department.

2. Contact Public Works Inspections at (816) 969-1800 at least 48 hours prior to the onset of construction.

3. Contact a Right-of-Way Inspector at (816) 969-1800 prior to any land disturbance within the right-of-way. These activities may require a permit.

4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

5. Submit a Land Disturbance Permit application and the required attachments to the Erosion Control Specialist prior to any land disturbance activities that are to occur prior to obtaining a building permit from the Codes Department. Approval of these plans does not constitute approval of the erosion control plan. Contact Barton Reese at (816) 969-1800 for new land disturbance permitting details.

Planning Review	Hector Soto (816) 969-1604	Planner Hector.Soto@cityofls.net	No Comments
------------------------	-------------------------------	-------------------------------------	-------------

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Condition(s) of Approval
--------------------	----------------------------	--	-----------------------------

1. Fire Department-All building and life safety issues shall comply with the 2006 International Fire Code and local amendments as adopted by the City of Lee's Summit.

2. Fire Department-A fire hydrant shall be located within 100 feet of the fire department connection (FDC).

The FDC shall be located at the northeast (right front) corner of the building.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------
