

PLANNING AND DEVELOPMENT

Commercial Final Development Plan Applicant's Letter

Date: Friday, June 12, 2015

To:

Property Owner: CITY OF LEES SUMMIT Email: Fax #: <NO FAX NUMBER>

Applicant: Public Works Admin Email: Fax #: <NO FAX NUMBER>

From: Hector Soto, Planner

Re:

Application Number: PL2015082

Application Type: Commercial Final Development Plan

Application Name: MAINTENANCE FACILITY SALT DOME IMPROVEMENTS **Location:** 1971 SE HAMBLEN RD, LEES SUMMIT, MO 64082

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Permitting and Plan Review Division of the Codes Administration Department at 816-969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See comments below to determine the required revisions. Submit six (6) full size sets (no larger than 24"x36") and one (1) half size set (11"x17" or 12"x18") of revised drawings. These shall be folded and collated in sets to approximately 8-½"x11" in size to the Planning and Codes Administration Department. Revised plans will be reviewed within five (5) business days of the resubmittal.

Required Corrections:

Engineering Review Gene Williams Senior Staff Engineer Corrections
(816) 969-1812 Gene.Williams@cityofls.net

- 1. A backflow device will be necessary for the proposed 2" hydrants.
- 2. It appears curb and gutter will need to be placed at the edge of pavement.
- 3. An Engineer's Estimate of Probable Construction Costs should accompany your final submittal drawings. The Engineering Plan Review and Inspection Fee is based on this estimate, and calculated at 3% of the total project cost, plus a \$100 per trip fee for the collection of water samples. Items to include in the estimate are: 1) grading for parking lot expansion, 2) pavement, 3) curb and gutter, 4) subgrade preparation, including the area one (1) foot beyond the back of curb, 5) final restoration, including sodding, seeding, fertilizer, mulch, and topsoil.

Planning Review	Hector Soto	Planner	Corrections
	(816) 969-1604	Hector.Soto@cityofls.net	

- 1. CURBING. CG-1 curbing shall be provided around the boundary of the expanded paved area.
- 2. BUILDING ELEVATIONS. Architectural drawings for the proposed 28' x 20' building shall be provided. The drawings shall identify the exterior building materials and proposed material colors.
- 3. LIGHTING. Are any new exterior light fixtures such as parking lot light poles or wall-mounted light fixtures proposed as part of this project? If so, show them on the site plan or building elevations to the extent possible. Parking lot light pole fixtures are subject to the requirements of Section 7.250 of the Unified Development Ordinance (UDO). Wall-mounted fixtures are subject to the requirements of Section 7.260 of the UDO.

Fire Review	Jim Eden	Assistant Chief	Pending
	(816) 969-1303	Jim.Eden@cityofls.net	