
PUBLIC WORKS ENGINEERING DIVISION

Date: Thursday, August 13, 2015

To:

HDR/ARCHER

Email: Dan.McGhee@HDRINC.COM

Fax #: (816) 347-1197

From: Gene Williams, P.E.

Senior Staff Engineer

Application Number: PL2015123

Application Type: Engineering Plan Review

Application Name: The Trails of Park Ridge 2nd Plat Water Line Extension

The Public Works Department received plans for this project on July 17, 2015. These plans are dated and were sealed on [July 17, 2015](#). We have completed our review and offer the following comments:

Engineering Review

1. All Sheets: Please change "CRT" to "CT" for NE Timberlake Ct.
2. Sheet 02C-WA-02: It appears that an additional gate valve is required near the intersection of NE Timberlake Ct. and NE Parkwood Dr.
3. All Profile View Sheets: Please specify 7 feet maximum cover in addition to the minimum cover requirement.
4. Water model information will be supplied to you within the next ten (10) business days. This information will be needed in order to apply for the MDNR Construction Permit.

If you have any questions or comments, please contact me, Gene Williams either at (816) 969-1800 or e-mail to Gene.Williams@cityofls.net.

Sincerely,

Original Signed

Gene Williams, P.E.

Senior Staff Engineer

cc: Development Engineering Project File