
PUBLIC WORKS ENGINEERING DIVISION

Date: Tuesday, June 14, 2016

To:

WARGER ASSOCIATES LLC

Steve Warger, P.E.

Email: STEVE@WARGERASSOCIATES.COM

Fax #: <NO FAX NUMBER>

From: Gene Williams, P.E.

Senior Staff Engineer

Application Number: PL2016037

Application Type: Engineering Plan Review

Application Name: Napa Valley 3rd Plat Sanitary Sewer

The Public Works Department received plans for this project on May 16, 2016. We have completed our review and offer the following comments:

Engineering Review

1. Please change the title of the plans to "Napa Valley 3rd Plat".
2. Sheet 3 of 8: Please add a note that the majority of the sanitary sewer serving this phase was completed in Phase 2, and to refer to the Phase 2 plans for location of the private sanitary sewer stubs. This information is needed for builders who are obtaining building permits in the future.
3. Sheet 4 of 8: Please "gray-out" the existing sanitary sewer.
4. Sheet 6 of 8: Please show the pipe on the profile view. There was no pipe shown on the profile view.
5. Sheet 6 of 8: It does not appear that the minimum fall at the connection point was achieved. Where a ninety degree angle exists, 0.5 feet of fall is required.
6. Since the sanitary sewer extension is less than 1000 feet, no MDNR permit is required.

In order to calculate the Public Works' Engineering Plan Review and Inspection Fee, a sealed Engineer's Opinion of Probable Construction Costs shall accompany your final submittal copies. The itemized estimate (material and installation) shall be sufficiently broken down and shall include the following items, as applicable.

- Public infrastructure, both onsite and offsite.

- Private street construction, including parking lots and driveways.
- Sidewalks located within the right-of-way.
- ADA accessible ramps.
- Sanitary sewer manholes and piping between manholes, including private mains.
- Connection of the building sanitary sewer stub to the public main.
- Waterlines larger than 2 inches in diameter, valves, hydrants, and backflow preventer with vault, if outside the building.
- Stormwater piping greater than 6 inches in diameter, structures, and detention / retention facilities - public or private.
- Water quality features installed to meet the 40-hour extended duration detention requirements.
- Grading for detention / retention ponds.
- Grading to establish proper site drainage.
- Utility infrastructure adjustments to finished grade (i.e. manhole lids, water valves, etc.).
- Erosion and sediment control devices required for construction.
- Re-vegetation and other post-construction erosion and sediment control activities.

Electronic Plans for Re-submittal

Beginning Monday, May 23, 2016, all Planning application and development engineering plan re-submittals shall include an electronic copy of the documents as well as the required number of paper copies. Electronic copies will not be required for initial application submittals at this time as the plans are subject to change.

Electronic copies shall be provided on CD in the following formats

- Plats – All plats shall be provided in Tagged Image Format File (TIFF) group 4 compression.
- Engineered Civil Plans – All engineered civil plans shall be provided in pdf or Tagged Image Format File (TIFF) group 4 compression. All sheets shall be individually saved and titled with the sheet title.
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).
- It is requested that each plan sheet be a maximum of 2MB.

Please contact Staff with any questions or concerns you may have.

If you have any questions or comments, please contact me, Gene Williams either at (816) 969-1812 or e-mail to Gene.Williams@cityofls.net.

Sincerely,

Original Signed

Gene Williams, P.E.
Senior Staff Engineer

cc: Development Engineering Project File

