



**1 PHOTOMETRIC SITE PLAN**  
 1"=60'-0"  
 NORTH

MARK	MANUFACTURE	MODEL NUMBER	MOUNTING			FINISH	LAMPS		FITTURE QUANTITY	REMARKS
			RECESS	SURFACE	WALL		CODE	QUANTITY		
SL 1	PRESCOLITE	1152-962			X		26 W CFL	1	158	
SL 2	HUBBELL	LMC-30LU-4K-4			X	BRONZE	71 W LED	1	9	6
SL 3	HUBBELL	BRI-01		X		BRONZE	26 W CFL	1	28	7
SL 4	CREE	ARE-EDR-2MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	197 W LED	1	9	2,3,4
SL 5	CREE	ARE-EDR-2MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	197 W LED	2	1	1,3,4
SL 6	CREE	ARE-EDR-3MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	197 W LED	1	8	2,3,4
SL 7	CREE	ARE-EDR-3MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	197 W LED	2	2	1,3,4
SL 8	CREE	ARE-EDR-5M-DA-12-E-UL-BZ-350-40K		POLE		BRONZE	197 W LED	1	11	2,3,4
SL 9	CREE	PWY-EDG-5M-P3-02-E-UL-BZ-350-40K		BOLLARD		BRONZE	21 W LED	1	19	
SL 10	CONTECH	TLTO12V2RGB16CR		GROUND		BRONZE	1.8W/FT RGB LED	1	3	
SL 11	CREE	ARE-EDR-2/3MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	197 W LED	2	1	1, 3, 4

- REMARKS:
- 1 PROVIDE WITH (2) HEADS AT 180° FROM EACH OTHER.
  - 2 PROVIDE WITH (1) HEAD.
  - 3 MOUNT ON 20' POLE ROUND STRAIGHT STEEL, 80 MPH RATED, 4 FOOT SCREW-IN BASE.
  - 4 VERIFY EPA RATING OF POLE WITH MANUFACTURER.
  - 5 MOUNT IN SOFFIT OF ROOF OVERHANG BETWEEN GARAGE DOORS.
  - 6 MOUNT AT 12' AFG
  - 7 MOUNT UNDER CARPORT CANOPY

STATISTICS						
Description	Avg	Max	Min	Max/Min	Avg/Min	Avg/Max
Drive Area	2.3 fc	6.9 fc	0.4 fc	17.3:1	5.8:1	0.33:1
Property Line	0.0 fc	0.4 fc	0.0 fc	N/A	N/A	N/A

ARCHITECTURE  
 LANDSCAPE  
 ARCHITECTURE  
 INTERIORS  
 ENERGY SERVICES

**NSPJ**

ARCHITECTS PA  
 3515 W. 75TH ST., SUITE 201  
 PRAIRIE VILLAGE, KS 66208

P. 913.831.1415  
 F. 913.831.1563  
 NSPIARCH.COM  
 © COPYRIGHT 2015



NSPJ  
 ARCHITECTS PA  
 3515 W. 75TH ST., SUITE 201  
 PRAIRIE VILLAGE, KS 66208  
 P. 913.831.1415  
 F. 913.831.1563  
 NSPIARCH.COM  
 © COPYRIGHT 2015

A NEW APARTMENT COMMUNITY AT:  
**SUMMIT SQUARE**  
 LEE'S SUMMIT, MISSOURI

- DRAWING RELEASE LOG
- 03.04.2016 - PDP SUBMITTAL
  - 06.09.2016 - FDP SUBMITTAL
  - 07.01.2016 - 80% PROGRESS SET
  - 07.15.2016 - PERMIT SUBMITTAL
  - 08.05.2016 - BID SET
  - 09.15.2016 - PERMIT RESUBMITTAL

- REVISIONS
- ▲ 09.15.2016 - PERMIT RESUBMITTAL

**LS&A**  
 Lullmer Sommers  
 & Associates, P.A.  
 CONSULTING ENGINEERS  
 3639 SW Summerfield Drive, Suite A  
 Topeka, Kansas 66614-3974  
 Telephone: (785) 233-3232  
 FAX: (785) 233-0947  
 Email: lsapa@lsapa.com  
 LSA PROJECT NO. 1604011

DATE  
 06/09/2016  
 JOB NO.  
 575215  
 DRAWN BY:  
 CAD  
 SHEET NO.  
**E0.01**