
PLANNING AND DEVELOPMENT**Commercial Final Development Plan
Applicant's Letter**

Date: Wednesday, November 30, 2016

To:

Applicant: SHAFER KLINE & WARREN INC

Email: MATT.EBLEN@SKW-INC.COM

Fax #: (913) 888-7868

Property Owner: SAINT LUKES EAST HOSPITAL

Email:

Fax #: <NO FAX NUMBER>

Engineer: SHAFER KLINE & WARREN INC

Email: MATT.EBLEN@SKW-INC.COM

Fax #: (913) 888-7868

From: Hector Soto, Planner

Re:

Application Number: PL2016189

Application Type: Commercial Final Development Plan

Application Name: SAINT LUKE'S EAST PARKING LOT ADDTION (REAR)

Location: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

Electronic Plans for Resubmittal

Beginning Monday, May 23, 2016, all Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies. Electronic copies will not be required for initial application submittals at this time as the plans are subject to change.

Electronic copies shall be provided on CD in the following formats

- Plats – All plats shall be provided in Tagged Image Format File (TIFF) Group 4 compression.
- Engineered Civil Plans – All engineered civil plans shall be provided in Tagged Image Format File (TIFF) Group 4 compression. All sheets shall be individually saved and titled with the sheet title.
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).
- It is requested that each plan sheet be a maximum of 2MB.

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Permitting and Plan Review Division of the Planning and Codes Administration Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Hector Soto (816) 969-1604	Planner Hector.Soto@cityofls.net	Approved with Conditions
------------------------	-------------------------------	-------------------------------------	--------------------------

1. PLATTING. Platting of the subject property will not be required at this time for the parking lot improvement. Platting will be required for the future development of any portion of the parent tract and/or the dedication of right-of-way for future road extension through the property.

Engineering Review	Gene Williams (816) 969-1812	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. The Engineer's Estimate of Probable Construction Costs has been accepted for this project, and the Public Works Review and Inspection Fee of \$30,130.77 (which is based on 3% of the total infrastructure cost) must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit from the Codes Administration Department.

2. Contact Public Works Inspections at (816) 969-1800 at least 48 hours prior to the onset of construction.

3. Contact a Right-of-Way Inspector at (816) 969-1800 prior to any land disturbance within the right-of-way. These activities may require a permit.

4. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

5. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Complete
--------------------	----------------------------	--	----------

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------
