

PLANNING AND DEVELOPMENT

**Commercial Final Development Plan
Applicant's Letter**

Date: Tuesday, July 25, 2017

To:

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Property Owner: ALDERSGATE METHODIST
CHURCH

Email:

Fax #: <NO FAX NUMBER>

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Property Owner: DAVID PRICE (Summit Custom
Homes)

Email: david@summitcustomhomeskc.com

Fax #: (816) 246-2662

From: Christina Stanton, Senior Planner

Re:

Application Number: PL2017026

Application Type: Commercial Final Development Plan

Application Name: RESIDENCES AT ECHELON

Location: 350 SW M 150 HWY, LEES SUMMIT, MO 64082

Electronic Plans for Resubmittal

Beginning Monday, May 23, 2016, all Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies. Electronic copies will not be required for initial application submittals at this time as the plans are subject to change.

Electronic copies shall be provided on CD in the following formats

- Plats – All plats shall be provided in Tagged Image Format File (TIFF) Group 4 compression.
- Engineered Civil Plans – All engineered civil plans shall be provided in Tagged Image Format File (TIFF) Group 4 compression. All sheets shall be individually saved and titled with the sheet title.
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).
- It is requested that each plan sheet be a maximum of 2MB.

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost,

as well as other permit costs and related fees, please contact the Permitting and Plan Review Division of the Planning and Codes Administration Department at (816) 969-1200.

Review Status:

Approved: See below for any conditions of approval.

Required Corrections:

Planning Review	Christina Stanton (816) 969-1607	Senior Planner Christina.Stanton@cityofls.net	No Comments
------------------------	-------------------------------------	--	-------------

Engineering Review	Gene Williams (816) 969-1223	Senior Staff Engineer Gene.Williams@cityofls.net	Approved with Conditions
---------------------------	---------------------------------	---	--------------------------

1. The Engineer's Estimate of Probable Construction Costs has not been received. In order to calculate the Engineering Plan Review and Inspection Fee, please submit the estimate. .
2. Contact Development Services Inspections at (816) 969-1800 at least 48 hours prior to the onset of construction.
3. Contact a Right-of-Way Inspector at (816) 969-1800 prior to any land disturbance within the right-of-way. These activities may require a permit.
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.
5. If ground-breaking is scheduled to take place prior to issuance of a building permit, please submit a Land Disturbance Permit application and the required attachments/fees to the Development Services Department.
6. Any cut and / or fill operations, which cause public infrastructure to exceed the maximum / minimum depths of cover shall be mitigated by relocating the infrastructure vertically and / or horizontally to meet the specifications contained within the City's Design and Construction Manual.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2012 International Fire Code.
2. IFC 903.3.7- Fire department connections. The location of fire department connections shall be approved by the fire code official. Connections shall be a 4 inch Storz type fitting and located within 100 feet of a fire hydrant, or as approved by the code official.

Actions required:

1. Move the fire hydrant from the east side of the roundabout south of Building 7 to the island the east, south of Building 8.

2. Show the location of the FDC on Building 4.
3. Move the FDC closer to the corner of Building 3 to meet the 100'.

Traffic Review

Michael Park
(816) 969-1820

City Traffic Engineer
Michael.Park@cityofls.net

No Comments
