



LEE'S SUMMIT MISSOURI

Sept. 1, 2015

THHinc McClure
Attn: John V. Huss, P.E., CDT
1901 Pennsylvania Dr.
Columbia, MO 65202

**RE: Request for Modifications for Summit Innovation Center - Sanitary Sewer – PL-20151068
City Engineer Approval of Specified Items**

References: a) Letter from John Huss, THHinc McClure, dated Aug. 25, 2015
b) Email from Ryan Fuller with Revised Sanitary Sewer Route dated Aug. 13, 2015

The City of Lee's Summit approves your request for the design exceptions listed below based on the request in the referenced letter dated Aug. 25, 2015, and drawing contained in the Aug. 13, 2015 email. These exceptions may be incorporated into subsequent submittals necessary to complete the standard review and approval of construction plans by City Staff.

1. Construction of a "doghouse" manhole denoted as MH A9 in the drawing contained within the email dated Aug. 13, 2015 from Ryan Fuller, contingent upon the inclusion of A-LOK gasket material in rings around all pipes at the "doghouse" connection, and also contingent upon the cleaning of all surfaces and application of bonding agent prior to encasing the pipe connection with portland cement concrete.

SIGNED:

George M. Binger III, P.E.
City Engineer / Deputy Director of Public Works

cc: Jeff Thorn, P.E., Water Utilities Assistant Director of Engineering Services
Kent Monter, P.E., Development Engineering Manager

