June 26, 2017

Parrot Properties Inc. 11303 View High Drive Lee's Summit, MO 64081

Dear Parrot Properties Inc.:

Pursuant to the Missouri Clean Water Law, we have issued and are enclosing a General Permit for Sewer Extension Construction to Village at View High. Please review the requirements of your permit.

If you were adversely affected by this decision, you may be entitled to an appeal before the Administrative Hearing Commission (AHC) pursuant to 10 CSR 20-1.020 and Sections 644.051.6 and 621.250, RSMo. To appeal, you must file a petition with the Administrative Hearing Commission within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the Administrative Hearing Commission. Contact information for the AHC is as follows: Administrative Hearing Commission, United States Post Office Building, 131 W. High Street, P.O. Box 1557, Jefferson City, MO 65102, Phone: 573-751-2422, Fax: 573-751-5018,

Website: www.oa.mo.gov/ahc.

Nothing in this permit removes any obligations to comply with county or other local ordinances or restrictions.

If you have any questions concerning this permit, please do not hesitate to contact the Water Protection Program at P.O. Box 176, Jefferson City, MO 65102, 573-751-1300.

Sincerely,

WATER PROTECTION PROGRAM

Refaat Mefrakis, P.E., Chief

Engineering Section

RM:asn

Enclosure

c: Mr. David Lohe, City of Lee's Summit Mr. Matt Schlicht, Engineering Solutions



STATE OF MISSOURI DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



GENERAL PERMIT for SEWER EXTENSION CONSTRUCTION

The Missouri Department of	Natural Resources hereby issues a permit to:
Construction Permit ID: Title of Project: Owner: Address:	MOGC00233 Village at View High Parrot Properites Inc 11303 View High Drive Lee's Summit, MO 64081
	general site work appropriate to the scope and purpose of the project and will include all the necessary nplete and usable collection system. The construction of this project will be in the vicinity of the county siving Permit ID below:
County: Jackson	Receiving Permit ID: MO0101087
for the construction of (descri	ribed construction project):
1,906.29 lf of 12-inch PV	onstruction of approximately 1,023.67 If of 8 inch PVC SDR-26 and C SDR-26 gravity sewer lines with approximately 11 manholes to serve a grage flow of 126,160 gpd.
discharges to an existing s	f View High Drive and Chipman in Lees Summit within Jackson County and ystem to be treated at Atherton WWTF, MO-0101087. David Lilly, the Blue Valley Sewer District provided an acceptance letter dated May
RSMo, and regulation promu As the Department does not permit does not include appr	ed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, algated thereunder, or this permit may be revoked by the Department of Natural Resources (Department). examine structural features of design or the efficiency of mechanical equipment, the issuance of this oval of these features. he construction of water pollution control components; it does not apply to other environmentally
June 27, 2017 Issue Date	Edward B. Galbraith, Director Division of Environmental Quality
June 26, 2019	Saved of amb

David J. Lamb, Acting Director Water Protection Program

Expiration Date

APPLICABILITY

- 1. This permit authorizes the construction of gravity sewer extensions, force mains, and lift stations. Storage basins, considered part of the collection system, are also included. Earthen basins are not included under this General Sewer Extension Construction permit.
- 2. A Sewer Extension Construction Permit may be required by the department due to compliance and enforcement actions.
- 3. This permit does not apply to:
 - A. Earthen storage basins;
 - B. Projects located within an Approved Sewer Program. These include the City of Blue Springs, City of Columbia, City of Kansas City, City of Jefferson City, City of Joplin, City of Lebanon, City of Springfield, City of St. Peters, Duckett Creek Sewer District, and Metropolitan St. Louis Sewer District;
 - C. Projects funded by the Department of Natural Resources;
 - D. Projects that substantially deviate from the Design Guides in 10 CSR 20-8; and
 - E. Exempt projects unless requested by the applicant or required by enforcement.

PREREQUISITES:

- 1. The General Sewer Extension Construction Permit application, appropriate fee, and a schedule for construction with the date on which construction will begin and anticipated completion date.
- 2. The engineering report, as required, plans and specifications each signed and sealed by a professional engineer registered in the State of Missouri. A Summary of Design is an acceptable substitute for the engineering report required by this permit prerequisite.
- 3. The Design Certification form signed and sealed by a professional engineer registered in the State of Missouri certifying the design of the system was done in accordance with 10 CSR 20-6 and 10 CSR 20-8.
- 4. A statement from the continuing authority was received accepting the wastewater for treatment.
- 5. A statement from the continuing authority was received accepting the responsibility for operation, maintenance, and modernization of these facilities

PERMIT CONDITIONS:

- 1. Contact the department's appropriate regional office 48 hours prior to starting construction. Contact information can be found at http://dnr.mo.gov/regions/regions.htm.
- 2. This permit authorizes the activities and scope of work detailed in the plans and specifications submitted with the request.
- 3. The construction must be in accordance with the design certification stating the plans and specifications comply with 10 CSR 20-6 and 10 CSR 20-8.

PERMIT CONDITIONS: (continued)

- 4. State and Federal Law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the department's regional office per 10 CSR 20-7.015(9)(E)2.
- 5. Protection of drinking water supplies shall be in accordance with 10 CSR 20-8.120(10). "There shall be no physical connections between a public or private potable water supply system and a sewer, or appurtenance thereto which would permit the passage of any wastewater or polluted water into the potable supply. No water pipe shall pass through or come in contact with any part of a sewer manhole."
 - A. Sewers in relation to water works structures shall meet the requirements of 10 CSR 23-3.010 with respect to minimum distances from public water supply wells or other water supply sources and structures.
 - B. Sewer mains shall be laid at least ten feet (10') horizontally from any existing or proposed water main. The distances shall be measured edge-to-edge. In cases where it is not practical to maintain a ten foot (10') separation, the department may allow a deviation on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on either side of the sewer and at an elevation so the bottom of the water main is at least 18 inches above the top of the sewer. If it is impossible to obtain proper horizontal and vertical separation as described above for sewers, the sewer must be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 pounds per square inch to assure water tightness.
 - C. Manholes shall be located with the top access at or above grade level.
 - D. Manholes should be located at least ten feet (10') horizontally from any existing or proposed water main.
 - E. Sewers crossing water mains shall be laid to provide a minimum vertical distance of 18 inches between the outside of the water main and the outside of the sewer. This shall be the case where the water main is either above or below the sewer. The crossing shall be arranged so that the sewer joints will be equidistant and as far as possible from the water main joints. Where a water main crosses under a sewer, adequate structural support shall be provided for the sewer to maintain line and grade. When it is impossible to obtain proper vertical separation as stipulated above, one of the following methods must be specified:
 - 1) The sewer shall be designed and constructed equal to the water pipe and shall be pressure tested to assure water tightness prior to backfilling; or
 - 2) Either the water main or sewer line may be continuously encased or enclosed in a watertight carrier pipe which extends ten feet (10') on both sides of the crossing, measured perpendicular to the water main. The carrier pipe shall be of materials approved by the department for use in water main construction.

PERMIT CONDITIONS: (continued)

6. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of one acre or more to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the department's ePermitting system available online at www.dnr.mo.gov/env/wpp/epermit/help.htm.

See <u>www.dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm</u> for more information.


7. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the department's Water Protection Program at (573) 751-1300 for more information.

See www.dnr.mo.gov/env/wpp/401/ for more information.

- 8. If this project eliminates a wastewater treatment facility, then a full closure plan shall be submitted to the department's appropriate regional office for review and approval of any permitted wastewater treatment system being replaced. In accordance with 10 CSR 20-6.010(12), the closure plan must meet the requirements outlined in Standard Conditions Part III, Section I, of the Missouri State Operating Permit. Closure shall not commence until the submitted closure plan is approved by the department. Form J Request for Termination of a State Operating Permit, shall be submitted to the department's appropriate Regional Office for termination of any existing Missouri State Operating Permit, once closure is completed in accordance with the approved closure plan.
- 9. Submit a Statement of Work Completed Form to the department following completion of construction. Submit an electronic copy of the as built plans if the project was not constructed in accordance with previously submitted plans and specifications.

RECEIVED

MAY 0 9 2017





MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM Water Protection Program

APPLICATION FOR CONSTRUCTION PERMIT -SEWER EXTENSION

FOR DEPAR	TM	ENT USE	ONL	Y .
APP NO.	CP	NO.		
FEE RECEIVED \$300,00)	CHECK NO.	Operations.	
DATE RECEIVED	_C			Q

				5-	<u>4-11</u>			
NOTE ► PLEASE READ THE ACCOMPAN					9			
1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)								
1.1 Is this a Federal/State funded project?	☐ YES	☑ N/A Funding Age	ency:	Project #:				
1.2 Has the Department of Natural Resource ☐ YES Date of Approval:	s approve		s engineering	report*?				
1.3 Is a copy of the appropriate plans* and s	pecificatio	ns* included with this ap	plication? {	ZYES □ NO				
1.4 Is a summary of design* included with thi	s applicat	ion? 🛮 YES 🗌 NO)					
1.5 Is the appropriate fee included with this a	pplication	? (See instructions for a	appropriate fe	e.) 🗹 YES 🗌] NO			
* Must be affixed with a Missouri registered p	rofessiona	al engineer's seal, signat	ure and date.					
2.0 PROJECT INFORMATION 2.1 NAME OF PROJECT								
Village at View High (On-Site Sanitary)								
ADDRESS View High Drive and Chipman	CITY Lee's Sur	nmit	MO	ZIP CODE 64082	Jackson			
2.2 Legal Description: 1/4,	4, NW	1/4, Sec. 03 , T	47 , R 32	•				
2.3 Project Components (check all that apply): ☑ Gravity sewers □ Pumping stations □ Force mains □ Alternative sewer system □ Other (Describe below.) 2.4 PROJECT DESCRIPTION								
Sanitary Sewer Extension of an eight inch gravity system to serve 47 single family lots Will include the following: 3,050.66 L. F. of 15" With 16 manholes. 312 Unit Apartments, 215,000 sq. ft. office/retail/restaurant, 150 Unit Senior Facility 60 gpd * 3.0 people/residence * 312 units = 56,160 gpd 100 gpd * 1.8 people/unit * 150 Units = 27,000 gpd 215,000 sq. ft. / 1,000 per sq. ft. = 215 * 200 gpd = 43,000 gpd Total = 126,160 gpd								
2.5 DESIGN INFORMATION A. Population or number of lots to be served	by this ex	tension: 1 Mixed Develo	pment					
B. Estimated flow to be contributed by this ex	dension:	Design Average Flow:	126k gpd	Design Peak Hourl	y Flow: 5256 gph			
C. Industrial Wastes: Type:	Flo	w: gpd						
D. Receiving Sewer: Size: 15 inches	Cap	acity: 1575 gpm						
3.0 PROJECT OWNER								
NAME John Bondon, President		(816) 616-2208		E-MAIL ADDRESS				
ADDRESS 11303 View High Drive	CITY Kansas (City	MO	ZIP CODE 64134				
4.0 CONTINUING AUTHORITY: Permanent organization that will serve as the continuing authority for the operation, maintenance and modernization of the wastewater collection system.								
NAME City of Looks Summit (David Lobs)		TELEPHONE NUMBER WITH AF	REA CODE	E-MAIL ADDRESS	7			
City of Lee's Summit (David Lohe) ADDRESS	(816) 969-1800		STATE	david.lohe@cityof	IS.COM			
220 SE Green Street	Lee's Su	mmit	МО	64063				
4.1 A letter from the continuing authority, if different than the owner, is included with this application. YES V NO N/A								
5.0 ENGINEER ENGINEER NAME / COMPANY NAME		TELEPHONE NUMBER WITH AF	REA CODE	E-MAIL ADDRESS	8			
Matt Schlicht		(816) 623-9888		mschlicht@es-kc.	com			
ADDRESS 50 SE 30th Street	CITY Lee's Su	mmit	MO	ZIP CODE 64082				

6.0 RECEIVING WASTEWA	TER TREATMENT FACI	LITY			
NAME		TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS		
The City of Lee's Summit		(816) 939-1800	david.lohe@cityofls.com		
MISSOURI STATE OPERATING PERMIT #	F	REMAINING CAPACITY (GPD)			
MO 0101087		27 MGD			
6.1 Has the receiving treatm	ent facility agreed to acce	pt the additional wastewater flow?	☑ YES □ NO		
6.2 A letter from the receivin		cility, if different than the continuing	authority, is included with this application.		
knowledge and belief such in	formation is true, complete	e, and accurate, and if granted this	in this application and to the best of my permit, I agree to abide by the Missouri a appeal available to applicant under		
PROJECT OWNER SIGNATURE	Dec des				
PRINTED NAME			DATE		
John Bondon, President	•				
TITLE OR COPORATE POSITION		TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS		
President		(816) 616-2208			
Mail completed copy to:	MISSOURI DEPART WATER PROTECTION P.O. BOX 176 JEFFERSON CITY,		5		
MO 780-1632 (12-14)			Page 2 of 2		