

Village At View High Appartments Only Pre

ID	Total Demand (gpm)	Available Flow at Hydrant (gpm)	Critical Node ID	Critical Node Pressure (psi)	Critical Node Head (ft)	Design Flow (gpm)
2916	1,500.00	2,202.57	2916	20.00	1,027.16	2,202.55
2919	1,500.00	2,130.20	2919	20.00	1,021.16	2,130.20
561	1,500.00	2,015.33	561	20.00	1,023.16	2,015.32

Date: Wednesday, November 08, 2017, Time: 10:30:52, Page 1

Village At View High Apartments Only Post

	ID	Static Demand (gpm)	Static Pressure (psi)	Static Head (ft)	Fire-Flow Demand (gpm)	Residual Pressure (psi)	Available Flow at Hydrant (gpm)	Available Flow Pressure (psi)
1	2916	252.00	72.44	1,148.19	1,500.00	36.69	2,202.57	20.00
2	2919	0.00	75.04	1,148.19	1,500.00	36.82	1,917.75	20.00
3	561	0.00	74.18	1,148.19	1,500.00	33.96	1,829.85	20.00

Date: Wednesday, November 08, 2017, Time: 10:29:29, Page 1