
PLANNING AND DEVELOPMENT**Commercial Final Development Plan
Applicant's Letter**

Date: Thursday, February 01, 2018

To:

Property Owner: TAILOR MADE EXTERIORS LLC

Email:

Fax #: <NO FAX NUMBER>

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

From: Shannon McGuire, Planner

Re:

Application Number: PL2017250

Application Type: Commercial Final Development Plan

Application Name: TAILOR MADE LANDING

Location: 1600 SE HAMBLER RD, LEES SUMMIT, MO 64081

Electronic Plans for Resubmittal

Beginning Monday, May 23, 2016, all Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies. Electronic copies will not be required for initial application submittals at this time as the plans are subject to change.

Electronic copies shall be provided on CD in the following formats

- Plats – All plats shall be provided in Tagged Image Format File (TIFF) Group 4 compression.
- Engineered Civil Plans – All engineered civil plans shall be provided in Tagged Image Format File (TIFF) Group 4 compression. All sheets shall be individually saved and titled with the sheet title.
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).
- It is requested that each plan sheet be a maximum of 2MB.

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See comments below to determine the required revisions. Resubmit six (6) full size sets (no larger than 24"x36") folded to 8-½"x11", and one (1) digital copy following the electronic plan submittal guides as stated above of the revised drawings to the Development Services Department. Revised plans will be reviewed within five (5) business days of the resubmittal.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	No Comments
------------------------	-----------------------------------	---	-------------

Engineering Review	Sue Pyles (816) 969-1245	Staff Engineer Sue.Pyles@cityofls.net	Corrections
---------------------------	-----------------------------	--	-------------

1. Please revise the public water line material under the street to C900 with a casing pipe. Include the casing pipe standard detail to the plan set.
2. Sheet C.200: Please extend the Detention Basin Top Elevation leader arrow to the correct contour.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2012 International Fire Code.

For information only.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------
