



---

Mechanical | Plumbing | Electrical | Communications | Video

## Memorandum

Date: May 9, 2018

From: Rich Beardmore, P.E., LEED AP

To: Mick Slutter, Tim Baldrige, Brad Hus

Re: Summit Square 2 FDP Responses

We are in receipt of the Lee's Summit comments on the original FDP submittal dated April 27, 2018.

One comment in the Planning Review, #7, requested clarification on light fixture quantity and whether SL5 and SL8 were single or double heads.

A column was added to the fixture schedule noting the quantity of each fixture type and also clarified the SL5 and SL8 fixtures.

This information is on the revised Sheet E0.01.

If there are any questions, please contact me.