


SITE LIGHT FIXTURE SCHEDULE												FIXTURE QUANTITY	REMARKS
MARK	MANUFACTURE	MODEL NUMBER	MOUNTING			FINISH	LAMPS						
			RECESS	SURFACE	WALL		LED	FLOUR.	HID	CODE	QUANTITY		
SL 1	PRESCOLITE	1152-962			X			X		26 W CFL	1	91	
SL 2	HUBBELL	LMC-30LU-4K-4			X	BRONZE	X			71 W LED	1	15	6
SL 3	HUBBELL	BRI-01		X		BRONZE		X		26 W CFL	1	52	7
SL 4	CREE	ARE-EDR-2MB-DA-06-E-UL-BZ-525-40K		POLE		BRONZE	X			132 W LED	1	6	2,3,4
SL 5	CREE	ARE-EDR-4MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	X			197 W LED	1	3	2,3,4
SL 6	CREE	ARE-EDR-3MP-DA-06-E-UL-BZ-525-40K		POLE		BRONZE	X			132 W LED	1	13	2,3,4
SL 7	CREE	ARE-EDR-3MP-DA-06-E-UL-BZ-525-40K		POLE		BRONZE	X			132 W LED	2	2	1,3,4
SL 8	CREE	ARE-EDR-4MB-DA-12-E-UL-BZ-525-40K		POLE		BRONZE	X			197 W LED	2	4	1,3,4

REMARKS:

- 1 PROVIDE WITH (2) HEADS AT 180° FROM EACH OTHER.
- 2 PROVIDE WITH (1) HEAD.
- 3 MOUNT ON 20" POLE ROUND STRAIGHT STEEL, 80 MPH RATED.
- 4 VERIFY EPA RATING OF POLE WITH MANUFACTURER.
- 5 NOT USED
- 6 MOUNT AT 12' AFG
- 7 MOUNT UNDER CARPORT CANOPY

STATISTICS					
Description	Avg	Max	Min	Max/Min	Avg/Min
Drive Area	1.9 fc	6.0 fc	0.3 fc	20.01	6.3:1
Property Line	0.1 fc	0.5 fc	0.0 fc	N/A	N/A





1

PHOTOMETRIC SITE PLAN

1"=40'-0"

A NEW APARTMENT COMMUNITY AT:

SUMMIT SQUARE II

DONOVAN RD. & WARD RD.
LEE'S SUMMIT, MISSOURI

DRAWING RELEASE LOG

● 04.13.2018 - FDP SUBMITTAL

REVISIONS

▲ ● 05.11.2018 - CITY COMMENTS

DATE
04/13/2018
JOB NO.
614618
DRAWN BY:
CAD
SHEET NO.

E0.01

LS&A
Latimer Sommers
& Associates, P.A.
CONSULTING ENGINEERS

3639 SW Summerfield Drive, Suite A
Topeka, Kansas 66614-3974
Telephone: (785) 233-2232
FAX: (785) 233-0947
Email: lsapa@lsapa.com
LSA PROJECT NO. 1804007

ARCHITECTURE
LANDSCAPE
ARCHITECTURE
INTERIORS
ENERGY SERVICES

P. 913.831.1415
F. 913.831.1563
NSPARCH.COM
© COPYRIGHT 2015

