



PLANNING AND DEVELOPMENT

Final Plat Applicant's Letter

Date: Monday, September 17, 2018

To:

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Property Owner: CMH PARKS INC (David Price)

Email: david@summithomeskc.com

Fax #: <NO FAX NUMBER>

From: Jennifer Thompson, Planner

Re:

Application Number: PL2018152

Application Type: Final Plat

Application Name: MANOR AT STONEY CREEK, 4TH PLAT

Location:

Tentative Schedule

Submit revised plans by noon on Tuesday, October 02, 2018 (4 full size paper copies, 1 reduced 8 ½" x 11" copy, and 4 copies of the comment response letter).

Applicant Meeting: **None**

Planning Commission Meeting: October 25, 2018 at 05:00 PM

City Council date will be set after all subdivision related public improvements have been completed and a Certificate of Final Acceptance has been issued. In lieu of completion of public improvements, an escrow secured with cash or an irrevocable letter of credit shall be deposited with the City to secure the completion of all public improvements prior to scheduling a City Council date.

If the revised submittal deadline is not met or plans are deficient, the item will be moved to a later meeting and a new deadline will be set. Future deadlines and meeting dates can be found on the "Planning Commission Meeting Dates" handout. Dates are subject to change; we will keep you informed throughout the process.

Electronic Plans for Re-submittal

Beginning Monday, May 23, 2016, all Planning application and development engineering plan re-submittals shall include an electronic copy of the documents as well as the required number of paper copies. This will allow us to provide a higher level of electronic correspondence with our Planning Commission, City Council, and the City's GIS Division.

Electronic copies shall be provided on CD in the following formats

- Plats – All plats shall be provided in Tagged Image Format File (TIFF) group 4 compression.
- Engineered Civil Plans – All engineered civil plans shall be provided in Tagged Image Format File (TIFF) group 4 compression. All sheets shall be individually saved and titled with the sheet title.
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in Portable Document Format (PDF).
- Studies – Studies, such as storm and traffic, shall be provided in Portable Document Format (PDF).
- It is requested that each plan sheet be a maximum of 2MB.

Please contact Staff with any questions or concerns you may have.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at 816-969-1200.

Voluntary Residential Development Surcharge

In a combined effort with both the R-4 and the R-7 School Districts the City of Lee's Summit is working together to educate the development community on a new program, the "Lee's Summit Voluntary Residential Development Surcharge." This is a program which will help raise capital to build new schools for our community. Brochures are available at the front counter of both the Development Services Department. You can also find more information on the City of Lee's Summit web site at www.cityofls.net. (For more information please contact the Board of Education at 986-2400).

Analysis of Final Plat:

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	No Comments
Planning Review	Jennifer Thompson (816) 969-1239	Planner Jennifer.Thompson@cityofls.net	Corrections

1. Please submit an electronic copy of the legal description. Microsoft Word document or selectable text PDF are the preferred file formats. The legal description can be emailed to the planner's email address above.
2. An electronic version of the plat was not received, please submit with revisions.
3. The Manor at Stoney Creek, 4th Plat must follow The Reserve at Stoney Creek, 4th Plat in the order it is recorded due to the necessary sequencing of infrastructure construction to serve the developments.
4. Submit a single-family compatibility form for this plat.
5. Submit a closure report
6. Please see engineer's comment regarding sidewalks located within sidewalks.
7. A final plat shall be approved and recorded prior to any building permits being issued. All subdivision public improvements must be complete prior to approval of the final plat by the City Council unless security is provided in the manner set forth in UDO Section 16.340.

8. No final plat shall be recorded by the developer until the Director of Planning and Special Projects and the City Attorney have reviewed and approved the declaration of covenants and restrictions pertaining to common property as prepared in accordance with Section 5.330 of the UDO, and until the Director has received certification from the Missouri Secretary of State verifying the existence and good standing of the property owners' association required by Section 5.340 of the UDO. In addition, the approved Declaration of Covenants, Conditions and Restrictions shall be recorded prior to the recording of the final plat.

Engineering Review	Sue Pyles (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Corrections
---------------------------	-----------------------------	---	-------------

1. Show the sidewalk on SW Grindstone Circle extending to the Lot 112/113 lot line.
2. The U/E between Lots 115 & 116 is not centered, but is labeled as if it is centered. Review and revise.
3. The U/E between Lots 126 & 127 is shown as a 15' U/E but should be split between the two lots. The easement is not shown as centered, is it? Review and revise.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	Corrections
-----------------------	--------------------------------	--	-------------

1. LNA notes should include all lots adjacent to SW Georgetown Dr.

GIS Review	Kathy Kraemer (816) 969-1277	GIS Technician Kathy.Kraemer@cityofls.net	Pending
-------------------	---------------------------------	--	---------
