

DEVELOPMENT SERVICES

**Commercial Final Development Plan
Applicant's Letter**

Date: Monday, November 19, 2018

To:

Property Owner: CASE ENTERPRISE LLC

Email:

Fax #: <NO FAX NUMBER>

Applicant: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

Engineer: ENGINEERING SOLUTIONS

Email: MSCHLICHT@ES-KC.COM

Fax #: (816) 623-9849

From: Shannon McGuire, Planner

Re:

Application Number: PL2018133

Application Type: Commercial Final Development Plan

Application Name: LOT 295, NEWBERRY LANDINGS, 1ST PLAT

Location: 1445 SE BROADWAY DR, LEES SUMMIT, MO 64081

Electronic Plans for Resubmittal

All Planning application and development engineering plan resubmittals shall include an electronic copy of the documents as well as the required number of paper copies.

Electronic copies shall be provided in the following formats:

- Plats – All plats shall be provided in multi-page Portable Document Format (PDF).
- Engineered Civil Plans – All engineered civil plans shall be provided in multipage Portable Document Format (PDF).
- Architectural and other plan drawings – Architectural and other plan drawings, such as site electrical and landscaping, shall be provided in multi-page Portable Document Format (PDF).
- Studies – Studies, such as stormwater and traffic, shall be provided in Portable Document Format (PDF).

Please contact Staff with any questions or concerns.

Excise Tax

On April 1, 1998, an excise tax on new development for road construction went into effect. This tax is levied based on the type of development and trips generated. If you require additional information about this development cost, as well as other permit costs and related fees, please contact the Development Services Department at (816) 969-1200.

Review Status:

Revisions Required: One or more departments have unresolved issues regarding this development application. See

comments below to determine the required revisions and resubmit to the Development Services Department. Resubmit six (6) full size sets of plans (no larger than 24"x36") folded to 8-½"x11", four (4) copies of the comment response letter, and one (1) digital copy following the electronic plan submittal guides as stated above. Revised plans will be reviewed within five (5) business days of the date received.

Required Corrections:

Planning Review	Shannon McGuire (816) 969-1237	Planner Shannon.McGuire@cityofls.net	Approved with Conditions
------------------------	-----------------------------------	---	--------------------------

1. All light fixtures on properties that do not adjoin residential uses and/or districts shall not exceed 28 feet.
2. All landscaping used as screening for ground mounted equipment must be at a minimum the same height as the equipment being screened at the time it is planted.

Engineering Review	Sue Pyles (816) 969-1245	Senior Staff Engineer Sue.Pyles@cityofls.net	Approved with Conditions
---------------------------	-----------------------------	---	--------------------------

1. Private parking lots shall follow Article 12 of the Unified Development Ordinance for pavement thickness and base requirements.
2. Contact the Field Engineering Inspector at (816) 969-1200 at least 48 hours prior to the onset of construction.
3. The Engineer’s Estimate of Probable Construction Costs has been accepted for this project, and the Engineering Plan Review and Inspection Fee (which is calculated as 3% of the total infrastructure cost plus a water test inspection fee(s)), and the water tap and meter setup fee have been included. These must be paid prior to the issuance of an infrastructure permit and/or the final processing of a building permit. \$11,924.41
4. Please be aware that any future repair work to public infrastructure (e.g., water main repair, sanitary sewer repair, storm sewer repair, etc.) within public easements will not necessarily include the repair of pavement, curbing, landscaping, or other private improvements which are located within the easement.

Fire Review	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
--------------------	----------------------------	--	--------------------------

1. All issues pertaining to life safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises, and to the safety to fire fighters and emergency responders during emergency operations, shall be in accordance with the 2012 International Fire Code.
2. IFC 304.3.3 - Dumpsters and containers with an individual capacity of 1.5 cubic yards [40.5 cubic feet (1.15 m3)] or more shall not be stored in buildings or placed within 5 feet (1524 mm) of combustible walls, openings or combustible roof eave lines.

Dumpster enclosure not shown.

3. IFC 506.1 - Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type listed in accordance with UL

1037, and shall contain keys to gain necessary access as required by the fire code official. 506.1.1 Locks. An approved lock shall be installed on gates or similar barriers when required by the fire code official.

Knox padlock required on gate.

Traffic Review	Michael Park (816) 969-1820	City Traffic Engineer Michael.Park@cityofls.net	No Comments
-----------------------	--------------------------------	--	-------------

Building Codes Review	Joe Frogge (816) 969-1241	Plans Examiner Joe.Frogge@cityofls.net	No Comments
------------------------------	------------------------------	---	-------------
